



ओएनजीसी
ONGC

अशोक कुमार
कार्यकारी निदेशक
मुख्य विपणन अधिकारी
Ashok Kumar
Executive Director
Chief Marketing Officer

निगमित विपणन समूह

1315, प्रथम मंजिल, टावर - बी, दीनदयाल ऊर्जा भवन,
5, नेल्सन मंडेला मार्ग, वसंत कुंज, नई दिल्ली -110070
Corporate Marketing Group
1315, 1st Floor, Tower-B, Deendayal Urja Bhawan,
5, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070
☎ +91-11-2675 1315 / 1430
✉ chiefmarketing@ongc.co.in

Ref. No. ONGC/CORP-MKTG/PNGRB/2025-26

02.05.2025

To
The Secretary,
Petroleum and Natural Gas Regulatory Board,
World Trade Centre, Nauroji Nagar
New Delhi – 110029.

O/o Secretary
PNGRB
Diary No. 37237
Date 05/05/25
8535

Sub: Proposal for laying of dedicated pipeline (4" X 200 mts) from ONGC's Vanadurru South (VNSAA) well location of Rajahmundry Asset to the premises of gas customer M/s Hayagreeva Ceramics (P) Ltd., under regulation 19 (2) of PNGRB (Authorizing Entities to Lay, Build, Operate or Expand Natural Gas Pipelines) Regulations, 2010.

Refer: i) Letter dated 23.03.2025 from Hayagreeva Ceramics to PNGRB.
ii) Letter dated 06.02.2025 from Hayagreeva Ceramics to ONGC.

Dear Sir,

ONGC's Vanadurru South (VNSAA) field of Rajahmundry Asset is a small and isolated field. ONGC published the tender for sale of gas under Small & Isolated field policy, wherein M/s. Hayagreeva Ceramic Pvt Ltd, the sole bidder was awarded gas @ 2500 SCMD. As intimated by the gas customer, vide above referred letter, they failed to get the pipeline connectivity through the CGD entity, the gas supply to M/s Hygreeva Ceramics (P) Ltd., has not commenced.


The customer has requested ONGC to lay the gas supply line to their factory premises, due to above cited reasons. ONGC in principle agrees to the request subject to consideration of PNGRB.

In this regard, In terms of 19 (2) of PNGRB (Authorizing Entities to Lay, Build, Operate or Expand Natural Gas Pipelines) Regulations, 2010, a proposal is being submitted herewith by ONGC for laying of dedicated pipeline (4" X 200 mts) from ONGC's Vanadurru South (VNSAA) well location of Rajahmundry Asset to M/s Hayagreeva Ceramics premises.

The proposal for the said subject, along with requisite details as per regulatory requirement is enclosed as Annexure-A for kind consideration and authorization by the Board.

With Best Regards,

Yours Sincerely,


(Ashok Kumar)
Chief Marketing Officer

Annexure A

Details of proposed dedicated pipeline (4" X 200m) for supply of gas from ONGC's Rajahmundry Asset to M/s Hayagreeva Ceramics (P) Ltd., premises.

Gas supply details:

Tender no : RFP No. ONGC/RFP/RJY/VNSAA
NOA date : 29.02.2024
Gas quantity allocated : 2,500 SCMD
Quality : As is where is basis
Pressure : 1.0-3.0 Kg/cm²

Pipeline Design details:

| | | |
|----|--------------------------------------|-----------------------------|
| 1 | Design Pressure at Source | Max 16 Kg/cm ² g |
| 2 | Available Pressure at Source | 16 Kg/cm ² g |
| 3 | Terminal Drop | 2 Kg/cm ² g |
| 4 | Design Pressure at Terminal Point | 5 Kg/cm ² g |
| 5 | Operating Pressure at Terminal Point | 2 Kg/cm ² g |
| 6 | Pipeline Operating life | 10 years |
| 7 | Design Pressure of Pipeline | 120 Kg/cm ² g |
| 8 | Design Temperature | Ambient |
| 9 | Material of Construction | Carbon Steel |
| 10 | Pipeline Route | Within ROU |
| 11 | Line Pipe size | 4 inch |
| 12 | Design Codes | API 14 |
| 13 | SCADA | NA |

Route description:

