



Petroleum and Natural Gas Regulatory Board

Tower E, 4th Floor (E-400), NBCC World Trade Centre, Nauroji Nagar,
New Delhi – 110029

Phone No.: 011-24060151, E-mail: contact@pngrb.gov.in



PNGRB/Auth/2-NGPL(05)/2023

01st July, 2025

PUBLIC NOTICE

Petroleum and Natural Gas Regulatory Board (PNGRB) has received an application from Arcelor Mittal Nippon Steel India Limited (AMNS) under Regulation 19(2) of PNGRB (Authorizing entities too Lay, Build, Operate or Expand Natural Gas Pipelines) Regulations, 2008, for authorization of dedicated pipeline starting from Shell's Hazira LNG Terminal at Hazira, Gujarat to AMNS's Hazira Plant at Hazira, Gujarat. (Application enclosed as **Annexure - I**)

The details of the aforesaid dedicated pipeline as submitted by AMNS is given below:

1	Name of Entity	M/s ArcelorMittal Nippon Steel India Limited
2	Name of Pipeline	AMNS Hazira Dedicated Pipeline
3	Date of Commissioning	Approx. 6 months from the start of construction
4	Section wise capacity on the Pipeline (to be furnished for each section separately)	
	a) Number of Section	1 (One)
	b) Name of Section with Start and End Point	Shell Hazira LNG Terminal – AMNS Hazira Plant. Start Point: Shell's Hazira LNG Terminal End Point: AMNS Hazira Plant Length: Approx. 3kms Pipeline size: 16"
	c) Capacity (MMSCMD)	
	i) Volume Terms	i) 10 MMSCMD
	ii) Energy Terms	ii) 4,00,000 MMBtu/Day
5	Number of entry points	1 (One)
6	Location of Entry Points	Shell's Hazira LNG Terminal at Hazira, Surat, Gujarat
7	Number of Exit Point	1 (One)
8	Location of Exit Point	AMNS's Hazira plant at Hazira, Surat, Gujarat
9	Entry point wise capacity (to be furnished for each section separately)	10 MMSCMD
10	Estimated capital cost	Approx. Rs.35 crore

11	Technical Parameters	
	i) Inlet Pressure at entry Point	60-90 Bar g
	ii) Calorific value band at entry Point	9000 to 9880 kCal/SCM
	iii) Temperature	Min. 7°C to Max. 55°C
12	Integrated Route map indicating name of District through which the pipeline pass	Proposed line passes through Surat district only.
13	Percentage of utilization of pipeline	100% by AMNS

In terms of the provisions of Regulation 19(2) of PNGRB (Authorizing entities too Lay, Build, Operate or Expand Natural Gas Pipelines) Regulations, 2008, PNGRB seeks comments of general public with a view to ascertain whether, instead of a dedicated pipeline, the public interest would be better served if a natural gas pipeline is laid, built, operated or expanded.

Comments/views, if any, may be submitted within 15 days of publishing of this Public Notice through email at secretary@pngrb.gov.in with subject “Views/Comments on Application of Arcelor Mittal Nippon Steel India Limited to lay a dedicated pipeline from Shell Hazira LNG Terminal to AMNS Hazira Plant under Regulation 19(2) of NGPL Authorization Regulations” or in writing through post at above mentioned address.

Secretary