

Annexure-IX

FY2010-11

Supply	Flow
	MSM3/D
CHAINSA	8.252086

Deliveries	Flow
	MSM3/D
HERO MOTO	0.346
KAJARIA	1.4013
MSIL	2.941
OMAX AUTO	0.346
HNG-2	0.6055
Uttam Strip	0.173
Indo Alusys	0.0865
Dakshin	0.2422
FCC Clutch	0.5882
USG Boral	0.173
Parle Biscuit	0.1384
Rathi Bar	0.2595
Rathi Steel	0.9515

FY2011-12

Supply	Flow
	MSM3/D
CHAINSA	8.295

Deliveries	Flow
	MSM3/D
HERO MOTO	0.29
KAJARIA	0.92
MSIL	2.83
MANESAR-OTHERS	0.115
OMAX AUTO	0.115
HNG-2	0.345
Sharp Menthol	0.115
Uttam Strip	0.115
Dakshin	0.23
USG Boral	0.115
Parle Biscuit	1.61
Rathi Bar	0.23
Rathi Steel	0.69
RICO	0.23
Rathi Saria	0.345

FY2012-13

Supply	Flow
	MSM3/D
CHAINSA	8.6190017

Deliveries	Flow
	MSM3/D
HERO MOTO	0.5185
KAJARIA	0.7225
MSIL	2.941
MANESAR-OTHERS	0.1275
OMAX AUTO	0.17
CAPARO POWER	0.7225
HONDA CAR	0.0255
HNG-2	0.2975
SANDEN	0.0255
Richfield	0.034
HSIL-2	0.0085
Sharp Menthol	0.0595
Mica II	0.0085
Shan Tableware	0.017
Pelican Ceramics	0.0085
Feather touch	0.017
Uttam Strip	0.085
AMTEK II	0.0255
MICA-1	0.0255
KEI	0.017
Indo Alusys	0.0425
Continental Engine	0.0255
Arvind Press Caps	0.017
AV Infra	0.085
Dakshin	0.1445
Century	0.0255
HMSIL	0.2635
USG Boral	0.1445
Parle Biscuit	0.969
Rathi Bar	0.1275
Rathi Steel	0.5015
Hero Moto-1	0.034
RICO	0.204
Rathi Saria	0.1785

FY2013-14

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	14.579996

Deliveries	Flow
	MSM3/D
HERO MOTO	0.8235
KAJARIA	1.107
MSIL	4.7115
MANESAR-OTHERS	0.2025
OMAX AUTO	0.27
CAPARO POWER	1.593
HONDA CAR	0.1215
HNG-2	0.4725
SANDEN	0.0405
Richfield	0.054
Toyoda	0.0135
HSIL-2	0.0135
SAINT GOBAIN	1.242
Sharp Menthol	0.108
Mica II	0.0135
Shan Tableware	0.027
Pelican Ceramics	0.054
Feather touch	0.027
Uttam Strip	0.135
AMTEK II	0.0405
MICA-1	0.0405
KEI	0.027
Surya	0.0135
Indo Alusys	0.1215
Continental Engine	0.0405
Arvind Press Caps	0.027
AV Infra	0.135
Dakshin	0.189
Sunbeam	0.027
Century	0.135
HMSIL	0.729
USG Boral	0.2025
Parle Biscuit	0.108
Rathi Bar	0.2025
Rathi Steel	0.8235
IGP	0.0405
Hero Moto-1	0.054
Havell	0.054
RICO	0.324
Rathi Saria	0.216

FY2014-15

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	14.6795

Deliveries	Flow
	MSM3/D
HERO MOTO	0.36672386
KAJARIA	1.0631628
MSIL	3.9805251
CAPARO MARUTI	0.034500276
MANESAR-OTHERS	0.16674646
OMAX AUTO	0.22999795
CAPARO POWER	1.6927964
CMR NIKKEI	0.13376062
HONDA CAR	0.10354283
HNG-2	0.40243841
SANDEN	0.034612045
Richfield	1.0516248
Toyoda	0.012947459
HSIL-2	0.011439579
SAINT GOBAIN	1.0348294
Special Ceramics	0.017306028
Sharp Menthol	0.020317579
Mica II	0.013786154
Shan Tableware	0.028745596
Pelican Ceramics	0.50168487
Feather touch	0.030505533
Uttam Strip	0.11498241
AMTEK II	0.17862618
MICA-1	0.0378386
KEI	0.036904052
Surya	0.011439579
Indo Alusys	0.10354283
Continental Engine	0.034612045
Arvind Press Caps	0.020825891
AV Infra	0.064846913
Dakshin	0.15525
Sunbeam	0.122879
Century	0.068930782
Hema	0.014079473
HMSIL	0.62303534
FCC Clutch	0.040478494
USG Boral	0.1724736
Parle Biscuit	0.18596159
Rathi Bar	0.1725
Rathi Steel	0.6899912
IGP	0.31728204
Hero Moto-1	0.08066368
Havell	0.040478494
RICO	0.27603303
Rathi Saria	0.18391318

FY2015-16

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	14.7

Deliveries	Flow
	MSM3/D
HERO MOTO	0.454378935
KAJARIA	1.590417255
MSIL	3.930390307
CAPARO MARUTI	0.034078693
MANESAR-OTHERS	0.35901481
OMAX AUTO	0.227187448
CAPARO POWER	1.133110099
CMR NIKKEI	0.008287281
HONDA CAR	0.113594734
HNG-2	0.397520732
SANDEN	0.034189095
Richfield	0.050993914
Toyoda	0.011299791
HSIL-2	0
SAINT GOBAIN	1.674272466
Special Ceramics	0.096610868
Sharp Menthol	0.079456631
Mica II	0.013617691
Shan Tableware	0.028394333
Pelican Ceramics	0.046537161
Feather touch	0.030132764
Uttam Strip	0.113577358
AMTEK II	0.056482835
MICA-1	0.173689903
KEI	0.025207216
Surya	0.238489262
Indo Alusys	0.056788677
Continental Engine	0.147783825
Arvind Press Caps	0.022889316
AV Infra	0.015934388
Dakshin	0.153352891
Sunbeam	0.029415254
Century	0.068088468
Hema	0.799370349
HMSIL	0.485301168
FCC Clutch	0.097931485
USG Boral	0.21563356
Parle Biscuit	0.113464931
Rathi Bar	0.170392101
Rathi Steel	0.624771036
IGP	0.034189095
Hero Moto-1	0.079677993
Havell	0.039983858
RICO	0.272659988
Rathi Saria	0.18166581
Sant AL	0.011359473
Jhalani	0.159032627

FY2016-17

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	14.75

Deliveries	Flow
	MSM3/D
HERO MOTO	0.316857261
KAJARIA	1.690741508
MSIL	3.426088622
CAPARO MARUTI	0.012515739
MANESAR-OTHERS	0.403016197
OMAX AUTO	0
CAPARO POWER	1.239077036
CMR NIKKEI	0.020153555
HONDA CAR	0.100767327
HNG-2	0.347087459
SANDEN	0.020153465
Richfield	0.017841885
Toyoda	0.01119637
HSIL-2	0.01119637
SAINT GOBAIN	1.399380206
Special Ceramics	0.01119637
Sharp Menthol	0.011137544
Mica II	0.022275076
Shan Tableware	0.027986635
Pelican Ceramics	0.592492032
Feather touch	0.016794845
Uttam Strip	0.111946566
AMTEK II	0.026499925
MICA-1	0.156513856
KEI	0.036041652
Surya	0.235064933
Indo Alusys	0.06269967
Continental Engine	0.067178218
Arvind Press Caps	0.022560663
AV Infra	0.036892878
Dakshin	0.15115099
Sunbeam	0.028992898
Century	0.011137544
Hema	0.013707737
HMSIL	0.261193803
FCC Clutch	0.110804245
USG Boral	0.165697703
Parle Biscuit	0.119673215
Rathi Bar	0.167945545
Rathi Steel	0.61580033
IGP	0.017751183
Hero Moto-1	0.040357191
Havell	0.024079248
RICO	0.257548229
Rathi Saria	0
Sant AL	0.013422163
Jhalani	0.188748643
NHK Spring	0.100767327
Rockman	0.078374587
Ahresty	0.033589109
Wanfeng	0.31349835
Minda	0.167945545
Agrawal Metal	0.033589109
AURONEXT	0.01119637
JF Casting	0.022392739
Mehru	0.078374587
RSGL	0.111963696
SPOT Customers	1.153226073

FY2017-18

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	14.75

Deliveries	Flow
	MSM3/D
HERO MOTO	0.316596043
KAJARIA	1.689347657
MSIL	3.423264147
CAPARO MARUTI	0.012505421
MANESAR-OTHERS	0.40268395
OMAX AUTO	0
CAPARO POWER	1.238055538
CMR NIKKEI	0.020136941
HONDA CAR	0.100684254
HNG-2	0.348031904
SANDEN	0.020136851
Richfield	0.017827176
Toyoda	0.014543281
HSIL-2	0.011128362
SAINT GOBAIN	1.398226554
Special Ceramics	0.011187139
Sharp Menthol	0.011128362
Mica II	0.022256713
Shan Tableware	0.027963563
Pelican Ceramics	0.59200358
Feather touch	0.016781
Uttam Strip	0.111854277
AMTEK II	0.026478079
MICA-1	0.156384826
KEI	0.036011939
Surya	0.234871145
Indo Alusys	0.06264798
Continental Engine	0.067123977
Arvind Press Caps	0.022542064
AV Infra	0.036862463
Dakshin	0.151026381
Sunbeam	0.028968996
Century	0.011128362
Hema	0.013696437
HMSIL	0.260978474
FCC Clutch	0.110712898
USG Boral	0.165561101
Parle Biscuit	0.119574556
Rathi Bar	0.16780709
Rathi Steel	0.615292663
IGP	0.017736549
Hero Moto-1	0.040323921
Havell	0.024059397
RICO	0.257335905
Rathi Saria	0
Sant AL	0.013411098
Jhalani	0.188593038
NHK Spring	0.106277734
Rockman	0.079782527
Ahresty	0.031324057
Wanfeng	0.313240533
Minda	0.16780844
Agrawal Metal	0.033385075
AURONEXT	0.015693844
JJF Casting	0.024706696
Mehru	0.073065042
RSGL	0.111852956
SPOT Customers	1.153159475

FY2018-19

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	14.78

Deliveries	Flow
	MSM3/D
HERO MOTO	0.331705595
KAJARIA	2.062794169
MSIL	3.586566745
CAPARO MARUTI	0.0103658
MANESAR-OTHERS	0.103657998
CAPARO POWER	1.96950197
HONDA CAR	0.124389598
rockman	0.093292199
HNG-2	0.362802994
SANDEN	0.0310974
Richfield	0.041463199
Nippon steel	0.041463199
Toyoda	0.0103658
Mikuni	0.0310974
HSIL-2	0.0103658
SAINT GOBAIN	2.342670764
Special Ceramics	0.0207316
Shiva Stainless Steel	0.0103658
Sharp Menthol	0.0103658
Mica II	0.0207316
Shan Tableware	0.0310974
Pelican Ceramics	0.0207316
Feather touch	0.0207316
Uttam Strip	0.103657998
AMTEK II	0.041463199
MICA-1	0.041463199
KEI	0.051828999
Surya	0.0103658
JJF Casting	0.0207316
Indo Alusys	0.062194799
Continental Engine	0.082926399
Arvind Press Caps	0.0207316
Sant Al	0.0207316
AURONEXT	0.041463199
Agrawal Metal	0.072560599
Orient Ceramics	0.0103658
Matod	0.041463199
Murti Udyog	0.0103658
AJANTA chem	0.0310974
APM	0.051828999
RELAXO	0.0207316
Mehru	0.0103658
Jaguar	0.051828999
RSGL Neemrana	0.238413396
Siddhi	0.0103658
AV Infra	0.051828999
Dakshin	0.134755398
Sunbeam	0.0207316
Century	0.103657998
Ajanta Soya	0.041463199
Sant AL 2	0.051828999
Hema	0.0207316
HMSIL	0.155486998
Jhalani	0.0310974
Ahresty	0.0310974
Adani IGL	0.134755398
FCC Clutch	0.103657998
USG Boral	0.155486998
Parle Biscuit	0.082926399
Rathi Bar	0.155486998
Rathi Steel	0.051828999
Wanfeng	0.290242396
Minda K	0.155486998
asian color	0.155486998
IGP	0.0310974
Hero Moto-1	0.072560599
Havell	0.0310974
RICO	0.248779196
NHK Spring	0.103657998
Mehsana	0.0310974

FY2019-20

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	12.634

Deliveries	Flow
	MSM3/D
HERO MOTO	0.288
KAJARIA	1.8048
MSIL	0.36
SUZUKI MOTORCYCLE	0.2112
MANESAR-OTHERS	0.192
CAPARO POWER	0.672
HONDA CAR	0.3168
rockman	0.096
HNG-2	0.336
SANDEN	0.0192
Richfield	0.0384
Nippon steel	0.0384
Toyoda	0.0192
Mikuni	0.0384
HSIL-2	0.0096
SAINT GOBAIN	1.9488
Special Ceramics	0.0192
Shiva Stainless Steel	0.0096
Mica II	0.0192
Shan Tableware	0.0288
Pelican Ceramics	0.0192
Uttam Strip	0.096
AMTEK II	0.0288
MICA-1	0.0384
KEI	0.048
Surya	0.0096
JJF Casting	0.0288
Indo Alusys	0.0576
Continental Engine	0.096
Sant Al	0.0192
AURONEXT	0.048
Agrawal Metal	0.096
Orient Ceramics	0.0288
Matod	0.0576
RELAXO	0.048
Mehru	0.0192
Jaguar	0.048
RSGL Neemrana	0.3456
Siddhi	0.0096
Dakshin	0.0248
Sunbeam	0.0192
Century	0.096
Sant AL 2	0.048
Hema	0.0192
HMSIL	0.096
Jhalani	0.0192
HCGKPL	0.096
Adani IGL	3.072
FCC Clutch	0.096
USG Boral	0.144
Parle Biscuit	0.0768
Rathi Bar	0.144
Rathi Steel	0.048
Wanfeng	0.288
Minda K	0.192
asian color	0.096
IGP	0.0288
Hero Moto-1	0.1056
Havell	0.0288
RICO	0.192
NHK Spring	0.096

FY2020-21

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	12.73

Deliveries	Flow
	MSM3/D
HERO MOTO	0.206145098
KAJARIA	0.809022271
MSIL	0.645013749
CAPARO MARUTI	0.008834245
SUZUKI MOTORCYCLE	0.070011543
MANESAR-OTHERS	0.473226168
OMAX/RICO	0.064825502
CAPARO POWER	1.33929488
CMR NIKKEI	0.108906844
HONDA CAR/FCC clutch/BORAL	0.26059852
rockman/wanfeng/asian color/minda	0.739613605
HNG-2	0
SANDEN	0.016206376
RICHF/IGP/HERO MOTO/HAVELL-2	0.06355786
PARLE G/PARLE NEW	0.059639462
Nippon steel	0.025930201
Toyoda	0.01166859
Mikuni	0.023974941
Deliv0005	0
HSIL-2	0.00648255
SAINT GOBAIN	0.423310531
Special Ceramics	0.014909866
Shiva Stainless Steel	0.00648255
Sharp Menthol	0.00648255
Mica II	0.0129651
Shan Tableware	0.018151141
Pelican Ceramics	0.012896865
Feather touch	0.014261611
Uttam Strip	0.065473757
Amtek I	0
AMTEK II	0.019447651
MICA-1	0.022688926
KEI	0.0324075
Surya Irrigation	0.00388953
JJF Casting	0.032412751
Indo Alusys	0.035654026
Continental Engine	0.051860402
Arvind Press Caps	0.013613356
Sant Al	0.032412751
AURONEXT	0.064825502
Agrawal Metal	0.048619127
Orient Ceramics	0.058342952
Matod	0.039543556
Murti Udyog	0.009723825
AJANTA chem	0.064825502
APM	0.032412751
RELAXO	0.023337181
Mehru	0.00907557
Jaguar	0.0324075
RSGL Neemrana	0.154284696
Siddhi	0.007130805
AV Infra	0.028523221
RathiBar/Specia/Dakshin	0
Century+Sunbeam	0.01037208
Century	0
Ajanta Soya	0.020744161
Sant AL 2	0.0129651
Hema	0.009755318
HMSIL	0.070659798
Jhalani	0.025936483
Ahresty	0.014909866
IGL Sakatpur	0.741603748
IGL Rewari	1.863733195
IGL Ajmer	0.005834295
IGL Bhiwadi	0.703356702
HCGKPL	0.044081342
Adani IGL	0.117334159
Adani Mahendragarh	0.27356362
Deliv0027	2.489856188

FY2021-22

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	12.73


Deliveries	Flow
	MSM3/D
HERO MOTO	0.206145098
KAJARIA	0.809022271
MSIL	0.645013749
CAPARO MARUTI	0.008834245
SUZUKI MOTORCYCLE	0.070011543
MANESAR-OTHERS	0.473226168
OMAX/RICO	0.064825502
CAPARO POWER	1.33929488
CMR NIKKEI	0.108906844
HONDA CAR/FCC clutch/BORAL	0.26059852
rockman/wanfeng/asian color/minda	0.739613605
HNG-2	0
SANDEN	0.016206376
RICHF/IGP/HERO MOTO/HAVELL-2	0.06355786
PARLE G/PARLE NEW	0.059639462
Nippon steel	0.025930201
Toyoda	0.01166859
Mikuni	0.023974941
Deliv0005	0
HSIL-2	0.00648255
SAINT GOBAIN	0.423310531
Special Ceramics	0.014909866
Shiva Stainless Steel	0.00648255
Sharp Menthol	0.00648255
Mica II	0.0129651
Shan Tableware	0.018151141
Pelican Ceramics	0.012896865
Feather touch	0.014261611
Uttam Strip	0.065473757
Amtek I	0
AMTEK II	0.019447651
MICA-1	0.022688926
KEI	0.0324075
Surya Irrigation	0.00388953
JJF Casting	0.032412751
Indo Alusys	0.035654026
Continental Engine	0.051860402
Arvind Press Caps	0.013613356
Sant Al	0.032412751
AURONEXT	0.064825502
Agrawal Metal	0.048619127
Orient Ceramics	0.058342952
Matod	0.039543556
Murti Udyog	0.009723825
AJANTA chem	0.064825502
APM	0.032412751
RELAXO	0.023337181
Mehru	0.00907557
Jaguar	0.0324075
RSGL Neemrana	0.154284696
Siddhi	0.007130805
AV Infra	0.028523221
RathiBar/Specia/Dakshin	0
Century+Sunbeam	0.01037208
Century	0
Ajanta Soya	0.020744161
Sant AL 2	0.0129651
Hema	0.009755318
HMSIL	0.070659798
Jhalani	0.025936483
Ahresty	0.014909866
IGL Sakatpur	0.741603748
IGL Rewari	1.863733195
IGL Ajmer	0.005834295
IGL Bhiwadi	0.703356702
HCGKPL	0.044081342
Adani IGL	0.117334159
Adani Mahendragarh	0.27356362
Deliv0027	2.489856188

FY2022-23

Supply	Flow
	MSM3/D
CHAINSA COMPRESSOR OUT	13.2

Deliveries	Flow
	MSM3/D
HERO MOTO	0.221996832
KAJARIA	1.500668342
MSIL	0.938575545
SUZUKI MOTORCYCLE	0.075493894
MANESAR-OTHERS	0.139557832
CAPARO POWER	1.441846002
HONDA CAR	0.084799733
rockman	0.13272543
HNG-2	0.244188824
SANDEN	0.021631718
Richfield	0.027942967
Nippon steel	0.027942967
Toyoda	0.012458648
Mikuni	0.025807205
HSIL-2	0.006941248
SAINT GOBAIN	0.967276787
Special Ceramics	0.023521395
Shiva Stainless Steel	0.007485754
Mica II	0
Shan Tableware	0.019577877
Pelican Ceramics	0.013882497
Uttam Strip	0.080571318
AMTEK II	0.020895095
MICA-1	0
KEI	0.036361746
Surya	0.006941228
JJF Casting	0.034889868
Indo Alusys	0
Continental Engine	0.056050035
Sant Al	0.034884216
AURONEXT	0
Agrawal Metal	0.062801762
Orient Ceramics	0
Matod	0.057412066
RELAXO	0.034889868
Mehru	0.009788939
Jaguar	0.041867841
RSGL Neemrana	0
Siddhi	0.007883373
Dakshin	0
Sunbeam	0.01133913
Century	0
Sant AL 2	0.013882497
Hema	0.010500859
HMSIL	0.088491283
Jhalani	0.035066794
HCGKPL	0.047416684
Adani IGL	0.126593943
FCC Clutch	0.084244621
USG Boral	0
Parle Biscuit	0.066988546
Rathi Bar	0
Rathi Steel	0
Wanfeng	0.195383097
Minda K	0.172895217
asian color	0.55264597
IGP	0.018580732
Hero Moto-1	0.02794289
Havell	0.020823683
RICO	0.069779805
NHK Spring	0.066290505
Ahresty	0.016049339
CAPARO MARUTI	0.01325815
CMR NIKKEI	0.117229956
IGL Sakatpur	0.798280176
IGL Rewari	0.610572687
Arvind Press Caps	0.014653744
AV Infra	0.034889868
Feather touch	0.015351542
Murti Udyog	0.009769163
AJANTA chem	0.069779736
APM	0.034889868
Ajanta Soya	0.069081938
Sharp Menthol	0.013955947
HCGDL	1.312556828
Adani Nuh Palwal	0.329360352
Mehsana	0.028609692
IGX	0.267256388
Knaufl	0.120021145
Eugia	0.069779736
RHI Mag	0.062801762
Honda Motorcycle	0.06070837
Jindal Al	0.07396652
Torrent Neemrana	1.032042291

This drawing and the design it covers are the property of ENGINEERS INDIA LIMITED. They are merely loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and private use permitted by any written consent given by lender to the borrower.



071-GN-CT-101 A/B/C/D
GAS FILTERS

071-KA-CF-101 A/B
GAS TURBINE COMPRESSORS

LEGEND:
 - - - - - EXISTING LINE
 - - - - - NEW LINE
 * GTC VENDOR SCOPE

NOTES:

- SAFETY VALVE TO BE LOCALLY VENTED AT SAFE ELEVATION. VENTS FROM DEPRESSURISING LINES TO BE IN A SAFE AREA 20M AWAY FROM COMPRESSOR STATION AND AT AN ELEVATION NOT LESS THAN 3M ABOVE THE HIGHEST OPERATING LEVEL IN THE COMPRESSOR STATION. ALL VENT LINES TO HAVE RAIN CAP AT TOP AND DRAIN AT BOTTOM.
- ALL INSTRUMENT TAG NOS. SHALL BE PROCESSED BY UNIT NO. 071 I.E. T-2001 SHALL BE READ AS 071-T-2001.
- ALL THE INDICATIONS/RESPONDENCE OF INSTRUMENTS SHOWN IN THIS P&ID SHALL BE ON P&ID PANEL MOUNTED INSTRUMENTS WILL BE IN STATION COMMON PANEL.
- TO BE SUPPLIED BY GTC VENDOR AND SHALL BE DESIGNED FOR COMP. COMPENSATION (1+1) CONSIDERING THE TOTAL FUEL GAS REQUIREMENT. VENDOR TO PROVIDE COMPENSATION FOR COMMON FUEL GAS LINE COMMON TO DECADE COMPENSATION. FUEL GAS FLOW INDICATION TO BE PROVIDED IN THE CONTROL ROOM.
- DP-2006 TO BE SUPPLIED BY GTC VENDOR.
- MASTER CONTROL IS FUNCTIONALLY SHOWN & INDICATIVE ONLY. FINAL SCHEME SHALL BE IMPLEMENTED AS PER SPECIFICATION BY COMPRESSOR VENDOR.
- ESD BUTTON SHALL BE PROVIDED IN (SCADA) MCC. STATION COMMON PANEL.
- REFER P&ID 6988-07-02-41-1221 FOR TYPICAL DETAILS OF COMPRESSOR TRAIN.
- DELETED.
- INTERLOCK No.: ACQUIRED BY ACTION STATION ESD ON SCADA/ 071-KA-CF-101 A/B PANEL 071-AV-2008 071-AV-2009 071-AV-2010 071-AV-2011 071-AV-2012 071-AV-2013
- ESD LOGIC SHOULD NOT RESET UNTIL AND UNLESS ALL DESIRED ACTIONS ARE ACHIEVED.
- REFER LEGEND P&ID 6988-00-02-1201 FOR TYPICAL VALVES DETAIL.
- PROVISION OF BRASS LINE WITH SPOOL PIECE FOR INSTALLATION OF FLOW METER DURING CALIBRATION.
- STRAIGHT LENGTH AS PER INSTRUMENTATION REQUIREMENT.
- FLOW COMPENSATION SHOULD BE DONE IN FLOW COMPUTER.
- ANTI SURGE CONTROL, PERFORMANCE CONTROL AND MASTER CONTROL FUNCTIONALLY SHOWN AND INDICATIVE ONLY. FINAL SCHEME SHALL BE IMPLEMENTED AS PER SPECIFICATION BY COMPRESSOR VENDOR.
- SIGNAL TO SCADA SHALL BE THROUGH SEPARATE SERIAL LINK FROM STATION PLC & EACH TRAIN UP?
- COMPRESSOR STATION INLET & OUTLET CONNECTION TO BE TAKEN FROM PROVISION KEPT FOR FUTURE COMPRESSOR UNDER VOBPL PROJECT.
- ALL INDICATIONS, RECORDING OF INSTRUMENTS, STATUS CONTROLS & ALARMS INDICATED IN THE P&ID SHALL BE IN COMMON FACILITY GTC PACKAGE VENDOR'S SCOPE.
- FOR SAMPLE CONNECTION DETAILS REFER P&ID NO. 6921-02-41-00-1202.
- HOOK UP TO BE TAKEN FROM STATION HEADER END FLANGE OF GREP COMPRESSORS.
- HOOK UP TO BE TAKEN AT END FLANGE OF GREP KALARAS COMPRESSOR DISCHARGE HEADER.
- FINE CASE PSV ON GAS FILTER TO BE PROVIDED BY FILTER VENDOR. COMPRESSOR DISCHARGE HEADER.
- GE/G/GT/G PACKAGE TO BE SUPPLIED BY VENDOR DRAWINGS SHALL BE REFERRED FOR DETAILS.
- HYDROCARBON DETECTORS SHALL BE PROVIDED FOR ALARM AT SURFACE STRATEGIC LOCATIONS TO MONITOR THE LEAKAGE OF FAILURE FROM EQUIPMENT PARTS, ACCESSORIES, VALVES & PIPES DEPENDING UPON THE WIND DIRECTION AND GAS DENSITY.
- GAS DETECTORS ARE TO BE PROVIDED AT DOWN WIND DIRECTIONS NEAR FILTERS, FLOW METERS, COMPRESSOR & FCG SKID. ALARM SIGNAL FROM GAS DETECTOR WILL BE TAKEN TO SMCs AND CONTROL ROOM.

5	ISSUED/REVISED AS PER HAZOP RECOMMENDATIONS & DORS	PR	PR
4	ISSUED/REVISED AS MARKED	PR	PR
3	ISSUED/REVISED AS MARKED	GR	MS
2	ISSUED/REVISED AS MARKED	GR	MS
1	ISSUED/REVISED AS MARKED	GR	MS
0	ISSUED FOR COMMENTS/ENGINEERING	BR	MS
	REVISIONS	DR	MS
	DATE	DR	MS


ENGINEERS INDIA LIMITED
(A Div. of India Understudy)

COMPRESSOR STATION WORKS AT KALARAS AND CHAINSA

CHAINSA COMPRESSOR STATION

SCALE	JOB NO.	DEPT.	SECTION	DWG. NO.	REV.
6988	02	41	071	1220	5

This drawing and the design it covers are the property of ENGINEERS INDIA LIMITED. They are merely loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and private use permitted by any written consent given by lender to the borrower.



- NOTES:**
1. THIS DRAWING SHOWS ONLY PROCESS INSTRUMENTATION. ALL INSTRUMENT MEASUREMENT REQUIRED FROM MACHINERY POINT OF VIEW ARE TO BE DETAILED BY VENDOR.
 2. COMPRESSOR STATION TO HAVE FACILITY FOR START/STOP FROM SCADA CONTROL CENTER.
 3. SAFETY VALVE TO BE LOCALLY VENTED AT SAFE ELEVATION. VENTS FROM DEPRESSURISING LINES TO SEPARATELY VENTED IN SAFE AREA AT A HEIGHT NOT LESS THAN 3M ABOVE THE HIGHEST OPERATING PLATFORM IN THE COMPRESSOR STATION AREA. ALL VENT PIPES SHALL BE PROVIDED WITH RAIN CAPS CAPS ON TOP AND DRAIN ON BOTTOM.
 4. COMMON TRIP ALARM FOR TRAINS TO BE TELEMETTERED TO SCADA.
 5. EMERGENCY SHUT DOWN PUSH BUTTON FOR COMP. TRAIN SHALL BE PROVIDED IN MCC, U/P, STATION COMMON PANEL & LOCAL AT EACH SHD.
 6. TO BE SUPPLIED BY GTC VENDOR. INSTRUMENT MARKED WITH * ARE ALSO IN GTC VENDOR'S SCOPE.
 7. ALL INSTRUMENT TAG NOS. SHALL BE PRECEDED BY UNIT NO-071, I.e. TI-2101 SHALL BE READ AS 071-2101.
 8. THIS P&ID INDICATES DETAILS OF A TYPICAL COMPRESSOR TRAIN. BOTH COMPRESSOR TRAINS ARE IDENTICAL EXCEPT INSTRUMENT AND PIPING SHALL HAVE SUFFIX A OR B RESPECTIVELY. E.G. PI-2102A SHALL BE READ AS PI-2102B FOR COMPRESSOR TRAIN 'B'.
 9. NORMAL SEAL GAS SUPPLY WILL BE TAKEN FROM COMPRESSOR DISCHARGE. PROVISION FOR START-UP/EMERGENCY SEAL GAS SUPPLY IS TAKEN FROM LINE PACK OF 48" ODR PL PRELINE AND NITROGEN CYLINDER BAYS. PROVISION FOR CHANGEOVER FROM NORMAL SEAL GAS SUPPLY TO EMERGENCY SEAL GAS SUPPLY IS UNDER GTC VENDOR'S SCOPE. VENDOR TO PROVIDE FLOW INDICATION AND ALARM IN SEAL GAS SUPPLY LINE. PRESSURE REDUCTION FACILITY, IF ANY REQUIRED IN SEAL GAS SYSTEM SHALL BE PROVIDED BY VENDOR.
 10. ALL THE INDICATIONS, RECORDING OF INSTRUMENTS AND ALL ANNUNCIATORS INDICATED IN THIS P&ID SHALL BE IN UNIT CONTROL PANEL AND SHALL BE REPEATED IN FLOW TRAIN PLC. PLC IS IN GTC PACKAGE'S SCOPE.
 11. ACOUSTIC INSULATION SHALL BE PROVIDED ON FOLLOWING LINES:
 - COMP. MIN. FLOW LINES AND SPILL BACK FLOW LINE.
 - COMP. SUC. LINE FROM SUCTION VALVE TO SUCTION NOZZLE COOLER.
 - COMP. DISCHARGE LINE FROM DISCHARGE NOZZLE TO AFTER COOLER.
 12. FUEL GAS FLOW SHALL BE INTEGRATED FOR ALL COMPRESSOR TRAINS & SHALL BE TELEMETTERED TO SCADA.
 13. XIC TO BE PROVIDED BY VENDOR.
 14. INTERLOCK NO. ACTUATED BY ACTION
 - 071-1-2A PT/PALL-2112A/13A/14A OPEN 071-FV-2101A (2 OUT OF 3)
 - PT/PALL-2109A/10A/11A OPEN 071-KA-CF-101A (2 OUT OF 3)
 - PT/PALL-2105A/06A/07A OPEN 071-KA-CF-101A (2 OUT OF 3)
 - PT/PALL-2104A/05A/10A OPEN 071-KA-CF-101A (2 OUT OF 3)
 - TI/TAHH-2106A/07A/08A (2 OUT OF 3)

LEGEND:

- EL - GTC PACKAGE VENDOR
- * - GTC PACKAGE VENDOR'S SCOPE.

REVISIONS:

NO.	DATE	REVISIONS	BY	CHKD.	APPD.
3		ISSUED AS PER HAZOP RECOMMENDATIONS & DOSH	MS	MS	MS
2		REVISIONS AS MARKED	MS	MS	MS
1		ISSUED FOR COMMENTS/ENGINEERING	MS	MS	MS
0		ISSUED FOR COMMENTS/ENGINEERING	MS	MS	MS


ENGINEERS INDIA LIMITED
 (A Coe. of India Undertaking)
 6988 02 41 071 1221

COMPRESSOR STATION WORKS AT KALARAS AND CHANSA

PIPING AND INSTRUMENTATION DIAGRAM
CHANSA COMPRESSOR STATION
TYPICAL COMPRESSOR DETAILS FOR COMPRESSOR TRAIN 'A'

6988 02 41 071 1221

This drawing and the design it covers are the property of ENGINEERS INDIA LIMITED. They are merely loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and private use permitted by any written consent given by lender to the borrower.



NOTES:-
1. INSTRUMENT MARKED WITH "*" IS IN OTC VENDOR'S SCOPE

1	INITIAL REVIEWED AS PER HAZOP RECOMMENDATIONS & DONE	DR	MS	MKA	AS
0	ISSUED FOR COMMENTS/ENGINEERING.	DR	MS	MKA	AS
	REVISIONS	DRN	BY	CHKD	APPD.
No.	DATE				

ENGINEERS INDIA LIMITED
(A Govt. of India Undertaking)

इंडिया लिमिटेड
(ए. गव. ऑफ इंडिया अंडरटैकिंग)

गैस अथॉरिटी ऑफ इंडिया लिमिटेड
GAS AUTHORITY OF INDIA LIMITED

कंप्रेसर स्टेशन वर्क्स अट कलारस अंड चानसा
COMPRESSOR STATION WORKS AT KALARAS AND CHANSA

प्रमाण SCALE	जॉब नं. JOB NO.	डिप्ट. DEPT.	सेक्शन SECTN.	यूनिट UNIT	डिजाइन नं. DWS. No.	रिवीज REV.
5	698802	41	071	1224	1	

वितरण रण्ड इंस्ट्रुमेंटेशन डायग्राम
PIPING AND INSTRUMENTATION DIAGRAM
UTILITY DISTRIBUTION AT CHINSA

डिस्ट्रिब्यूशन कोड
DISTRIBUTION CODE

PROCESS DESIGN BASIS FOR PMC SERVICES FOR COMPRESSOR STATIONS WORKS AT KAILARAS AND CHAINSA FOR VIJAIPUR –DADRI PIPELINE PROJECT

APPROVED	
GAIL	EIL

B	18.03.09	CLIENT'S INPUTS INCORPORATED & REISSUED FOR APPROVAL			
A	20.1.09	ISSUED FOR COMMENTS/APPROVAL	MKA	AS	AS
Rev. No	Date	Purpose	Prepared by	Checked by	Approved by

TABLE OF CONTENTS

1.0	INTRODUCTION
2.0	BASIC PARAMETERS
3.0	PROJECT SCOPE AND BATTERY LIMITS
4.0	PIPELINE PARAMETERS
5.0	COMPRESSOR STATION PARAMETERS
6.0	INSTRUMENTATION
7.0	SCADA & TELECOMMUNICATION SYSTEM
8.0	METEOROLOGICAL DATA
9.0	GENERAL PROJECT SPECIFICATIONS
10.0	SPECIAL CUSTOMER REQUIREMENTS
ANNEXURE –I	COMPOSITION OF GAS

1.0 INTRODUCTION:

GAIL (India) Limited, have awarded EIL the Project Management Consultancy Services for installation of new compressor stations and associated facilities in the proposed 48” Vijaipur –Dadri Pipeline being currently executed under Vijaipur-Dadri-Bawana Pipeline Project at Kailaras and Chainsa.

The project broadly covers installation of compressor stations at Kailaras ([228.036](#) Kms) downstream of Vijaipur near 2nd Intermediate Pigging Station) and at Chainsa([457.049](#) Kms) downstream of Vijaipur near 4th Intermediate Pigging Station) on new 48” Vijaipur-Dadri pipeline.

This design basis covers the design parameters for compressor stations.

2.0 BASIC PARAMETERS

2.1	Products to be transported	Gas
2.2	Product properties/specifications	As per Annexure-I.
2.3	Design codes	Latest edition of ASME B31.8 and OISD-226 Guidelines will be followed as applicable. However, in case of contradictory stipulations, the more stringent conditions will prevail.
2.4	Total compression capacity required	KAILARAS : 53.4 75 MMSCMD CHAINSA : 53.4 55 MMSCMD
2.5	Sparing philosophy for compressors	100% for Single compressors (1W+1S) 50% for two compressors (2W+1S) 33% for three compressors (3W+1S)
2.6	Type of compressor	Centrifugal
2.7	Type of driver	Gas Turbine
2.8	Type of intercooler and after cooler	Air cooler

3.0 PROJECT SCOPE AND BATTERY LIMITS

3.1 PROJECT SCOPE:

- Compressor Stations at Kailaras and Chainsa along with its auxiliaries, GTG/GEG/DEG etc.

3.2 BATTERY LIMITS :

3.2.1 Compressor Station at Kailaras : From/to existing 36” Tap-Offs provided at IPS-2 on 48” Vijaipur-Dadri pipeline.

3.2.2 Gas compositions : Annexure-I

3.2.3 Compressor Station at Chainsa : From/to existing 36” Tap-Offs provided at IPS-4 on 48” Vijaipur-Dadri pipeline.

3.2.4 Gas compositions : Annexure-I

4.0 PIPELINE PARAMETERS (UNDER EXECUTION)

4.1 Main pipeline diameter : 48” NB

4.2 Pipeline Roughness : 10 micron

4.3 Corrosion allowance : Nil

4.4 Subsoil temperature : 20-25 deg. C (1 meter below surface)

4.5 Chainage of IPS-2 (Kailaras) : 228.43036 km from Vijaipur

4.6 Chainage of IPS-4 (Chainsa) : 456.7457.049 km from Vijaipur

5.0 COMPRESSOR STATION PARAMETERS

5.1 Kailaras Compressor Station

Compressor suction pressure : As per hydraulics

Compressor suction temperature : As per hydraulics

Compressor discharge pressure : 99.93 kg/cm²_g

Total flow rate : 53-453.75 MMSCMD

Configuration : 2+1 (To be confirmed by compressor vendor)

5.2 Chainsa Compressor Station

Compressor suction pressure : As per hydraulics

Compressor suction temperature : As per hydraulics

Compressor discharge pressure : 99.93 kg/cm²_g

Total flow rate : ~~53.15~~53.5 MMSCMD

Configuration : 2+1 (To be confirmed by compressor vendor)

5.3 Utility specification (At Kailaras Compressor station)

S.NO	Parameters	Plant Air	Instrument Air	Nitrogen	Service Water
5.3.1	Source	From. Air Compressor	From. Air Compressor	From PSA Unit	Borewell
5.3.2	Dew Point	—	-40°C at atm. Pr.	—	—
5.3.3	Pressure, kg/cm ² _g (min/nor/design)	5.0/ 8.0 / 11.5	5.0/ 7.5 / 11.5	4.5	3.0
5.3.4	Temperature, ° C	55.0	55.0	Ambient	Ambient
5.3.5	Storage requirement	5 minutes hold-up	20 minutes hold-up	—	—
5.3.6	Consumption	Note:1	Note:1	Note:1	5 m ³ /hr (intermittent)
5.3.7	Quality	Oil Free	Oil Free	99.5% pure	

Note 1: Data will be firm-ed-up after the requirement is finalized by Compressor/GTC vendors during detailed engineering.

5.4 Utility specification (At Chainsa Compressor station)

S.NO	Parameters	Plant Air	Instrument Air	Nitrogen	Service Water
5.4.1	Source	From. Air Compressor	From. Air Compressor	From PSA Unit	Borewell
5.4.2	Dew Point	—	-40°C at atm. Pr.	—	—
5.4.3	Pressure, kg/cm ² _g (min/nor/design)	5.0/ 8.0 / 11.5	5.0/ 7.5 / 11.5	4.5	3.0
5.4.4	Temperature, ° C	55.0	55.0	Ambient	Ambient
5.4.5	Storage requirement	5 minutes hold-up	20 minutes hold-up	—	—
5.4.6	Consumption	Note:1	Note:1	Note:1	5 m ³ /hr (intermittent)
5.4.7	Quality	Oil Free	Oil Free	99.5% pure	

Note 1: Data will be firm-ed-up after the requirement is finalized by Compressor/GTC vendors during detailed engineering.

6.0 INSTRUMENTATION

6.1	General	Adequate instrumentation and control system will be provided for safe and efficient operation. The compressor station shall be monitored and controlled through Supervisory Control and Data Acquisition (SCADA) of DVBPL currently being executed which is designed for remote monitoring and control application. RTU/Flow computers shall be provided at compressor station for flow computation, signal transmission to SCADA and logic and control. All transmitters shall be smart transmitters.
6.2	Control Philosophy At Kailaras & Chainsa compressor stations	Two levels of controls viz. PLC & SCADA are envisaged. Individual compressor trains shall be operated from the respective unit PLC(only minimum critical parameters are available in Unit Control Panel (UCP)) Station facility and common equipment shall be operated from common PLC (only minimum critical parameters are available in Facility Control Panel (FCP)).
6.3	Compressor Control	CCC or equivalent.
6.4	Interlock & Shut down	PLC based.
6.5	Safety valve isolation	Safety valve isolation will be provided wherever required These isolation valves should be locked open.
6.6	Block & by-pass valve for control valves	As per design.
6.7	Type of control	Electronic
6.8	Final control element	Gas/Instrument air actuated for control valves and line gas for AVs.



7.0 SCADA & TELECOMMUNICATION SYSTEM

SCADA and Telecommunication systems being provided for Vijaiapur–Dadri-Bawana Pipeline Project shall be extended to include compressor stations to ensure effective and reliable control, management and supervision of the compressor stations from a centralized location using Remote Telemetry Units (RTU).

7.1 SCADA monitoring and control: The SCADA master control station (SMCS) shall be located at **NGMC, Noida.**

8.0 METEOROLOGICAL DATA

Location	Ambient temp. °C		Design Rh	Altitude, M above MSL	Air temp. considered for air cooler design,deg.C
	Min.	Max.			
Kailaras	2	46	84%@45°C	190.3	42
Chainsa	2	46	90%@35°C	197.8	42

9.0 GENERAL PROJECT SPECIFICATIONS

9.1 Numbering system to be followed:

9.1.1	Equipments	As per EIL standard
9.1.2	Instruments	As per EIL standard
9.1.3	Drawings/Documents	As per EIL standard
9.1.4	Unit No.	Kailaras CS : 070 Chainsa CS : 071
9.1.5	P&ID No.	Kailaras CS : <u>1210 - 1219</u> Chainsa CS : <u>1220 - 1229</u>

9.2 Units of Measurement: Metric, unless otherwise specified Gas flow rate shall be in MMSCMD

10.0 SPECIAL CUSTOMER REQUIREMENTS

10.1 ~~Since the compressor stations are installed at almost equal distances the specifications for compressors (suction pressure and compression ratio) shall be kept same in order to have the advantage of common spares DELETED.~~

10.2 Line down stream of compressor station should be piggable.

10.3 ~~Vendor to check the compressors at Chainsa and Kailaras for flow rate of 60MMSCMD (Check Case) and furnish the maximum discharge pressure achievable at Kailaras and Chainsa and also ensure minimum discharge pressure of 92kg/cm²g at Chainsa by various options such as variation of speed, taking standby train in line and bypass of excess gas DELETED.~~

ANNEXURE I

COMPOSITIONS OF GAS

(A) Rich gas (W/O C2/C3 extraction at DAHEJ)

S.NO	Component	Gas Composition, Mol%
1	C1	92.49
2	C2	5.64
3	C3	1.41
4	IC4	0.20
5	NC4	0.15
6	IC5	---
7	NC5	0.01
8	C6	---
9	N ₂	0.09
10	CO ₂	----
11	H ₂ S	6ppmw
12	Total Sulfur	24ppmw
	Total	100

(B) LEAN GAS (With C2/C3 extraction at Dahej)

S.NO	Name	Mol %
1	C1	94.07
2	C2	4.59
3	C3	1.07
4	IC4	0.18
5	NC4	---
6	IC5	---
7	NC5	---
8	C6	---
9	N ₂	0.09
10	CO ₂	---

11	H ₂ S	6 ppmw
12	Total Sulfur	24ppmw
	Total	100

Rich gas is mixture of Dahej RLNG + Spot LNG + Reliance gas .Lean gas is a mixture of gas after extraction of C2/C3 from RLNG at Dahej +Spot LNG + Reliance gas.

PROJECT	COMPRESSOR STATION WORKS AT KAILARAS & CHAINSA		CLIENT	GAIL	
UNIT	CHAINSA COMPRESSOR STATION		JOB NO.	6988	UNIT NO. 071
ITEM NO.	071-KA-CF-101A/B/C		SERVICE	NATURAL GAS COMPRESSOR	
TYPE	CENTRIFUGAL		LOCATION	CHAINSA (UNDER ROOF)	
NUMBER OF COMPRESSORS REQUIRED	IN REGULAR USE		NOTE-1	AS SPARE	NOTE-1
LUBRICATING OR NON-LUBRICATING TYPE					
TYPE OF DRIVER	REGULAR COMPRESSOR	GAS TURBINE DRIVEN			
	SPARE COMPRESSOR	GAS TURBINE DRIVEN			
NUMBER OF STAGES	ONE				
PROPERTIES OF GAS (COMPOSITION AT SUCTION)					
COMPOSITION	MOLE %				
		RICH GAS		LEAN GAS(NOTE-28)	
WATER VAPOUR		-		-	
HYDROGEN		-		-	
NITROGEN		0.09		0.09	
OXYGEN		-		-	
CARBON MONOXIDE		-		-	
CARBON DIOXIDE		-		-	
HYDROGEN SULPHIDE		6 PPMW		6 PPMW	
METHANE		92.49		94.07	
ETHYLENE		-		-	
ETHANE		5.64		4.59	
PROPYLENE		-		-	
PROPANE		1.41		1.07	
I-BUTANE		0.20		0.18	
N-BUTANE		0.15		-	
I-PENTANE		-		-	
N-PENTANE		0.01		-	
HAXANE PLUS (AVERAGE M. WT.)		-		-	
AMMONIA		-		-	
HYDROGEN CHLORIDE		-		-	
CHLORINE		-		-	
INERTS (AVERAGE M. WT.)		-		-	
AIR (DRY BASIS)		-		-	
H2O		NIL		NIL	
TOTAL SULFUR		24 PPMW		24 PPMW	
FLOW RATE (NORMAL)	NM3/HR	2109030 (NOTE-2)		2109030 (NOTE-2)	
	KG/HR				
AVERAGE M. WT.		17.4		17.07	
DENSITY	KG/M3	57.5	2	56.3	2
COMPRESSIBILITY FACTOR		0.872		0.877	
RATIO OF SPECIFIC HEATS (Cp/Cv)		1.28 (NOTE -18)		1.28 (NOTE -18)	
CORROSIVE / EROSION ELEMENTS		NONE		NONE	
PARTICLE SIZE OF EROSIONS (IF ANY)					
IS DESIGN FOR NACE CODE IS REQUIRED		NO		NO	
RATING					
SUCTION		600#(NOTE-26)		600#(NOTE-26)	
DISCHARGE		900#	2	900#	2
OPERATING CONDITIONS					
SUCTION PRESSURE	KG/CM2 G	74.1 (NOTE-3)		74.5 (NOTE-3)	
SUCTION TEMPERATURE	DEG C	34.5		34.4	
DISCHARGE PRESSURE	KG/CM2 G	99.93(NOTE-23)		99.93 (NOTE-23)	
DISCHARGE TEMPERATURE	DEG C	61.3 (NOTE-7)		61.2 (NOTE-7)	
COMPRESSION RATIO		1.344	2	1.337	1
AFTER COOLER BY VENDOR		YES (NOTE-21)		YES (NOTE-21)	
MAX DISCH. TEMP AT AFTERCOOLER EXIT	DEG C	55			
CONDENSATE FROM INTERSTAGES		NIL			
REFERENCE P&ID NUMBER (IF ANY)		NOTE-8			
2	24.02.2009	REVSED AS MARKED		MKA	AS AS
1	19.02.2009	REVISED AS PER CLIENT'S/ENGG. INPUTS		MKA	HKP HKP
0	02.01.2009	ISSUED FOR COMMENTS/ENGINEERING		MKA	AS AS
Rev. No.	Date	Purpose		Prepared By	Reviewed By Approved By

PROJECT	COMPRESSOR STATION WORKS AT KAILARAS & CHAINSA	CLIENT	GAIL	UNIT NO.	071
UNIT	CHAINSA COMPRESSOR STATION	JOB NO.	6988		
ITEM NO.	071-KA-CF-101A/B/C	SERVICE	NATURAL GAS COMPRESSOR		

NOTES:

- NO. OF COMPRESSORS

	IN REGULAR USE	SPARE
2	2	1
- ABOVE CONFIGURATION IS TENTATIVE ONLY, COMPRESSOR VENDOR TO CONFIRM THE FINAL CONFIGURATION. SPARING PHILOSOPHY SHALL BE ADOPTED KEEPING MINIMUM ONE THIRD OF THE GROSS CAPACITY AS SPARE MACHINE HAVING CAPACITY IDENTICAL TO REGULAR UNIT, SUBJECT TO MINIMUM OF ONE SPARE UNIT.
- TOTAL FLOW RATE TO COMPRESSORS. INDIVIDUAL COMPRESSOR CAPACITY SHALL DEPEND ON CONFIGURATION.
- SUCTION PRESSURE INDICATED IS AT THE SUCTION FLANGE OF THE COMPRESSOR. TEMPORARY STRAINER SHALL BE IN SUCTION LINE DURING START UP AND THE SAME SHALL BE REPLACED BY PERMANENT STRAINER SUBSEQUENTLY. STRAINER PRESSURE DROP OF 0.1 KG/CM² HAS BEEN CONSIDERED TO ARRIVE AT THE COMPRESSOR SUCTION PRESSURE.
- VENDOR TO PROVIDE THE MESH SIZE AND THE PRESSURE DROP ACROSS THE PERMANENT STRAINER.
- VENDOR SHALL SUPPLY PERFORMANCE CURVES FOR ALL CASES OF OPERATION.
- VENDOR TO ALSO INCLUDE IN THE SCOPE OF SUPPLY ALL NORMAL INSTRUMENTATION AND CONTROL FOR EFFICIENT OPERATION, SHUTDOWN AND SAFETY REQUIREMENTS AND ESSENTIAL ACCESSORIES.
- VENDOR TO CONFIRM THE COMPRESSOR DISCHARGE TEMPERATURE.
- APART FROM THE VENDOR'S SCOPE OF SUPPLY AS PER P&ID NO. 6988-02-41-071-1220 & 1221, VENDOR SHALL SUPPLY ADDITIONAL INSTRUMENTATION, CONTROL & SHUTDOWN LOGIC DEVICES FOR SAFE AND EFFICIENT OPERATION OF MACHINE.
- AUTOMATIC SPILL BACKS IS CONSIDERED FOR EACH COMPRESSOR.
- COMPRESSOR WILL START FROM CONTROL PANEL LOCATED IN MAIN CONTROL ROOM, HOWEVER, START CLEARANCE FROM FIELD WILL BE PROVIDED. MONITORING & CONTROL OF THE COMPRESSOR STATION SHALL BE PERFORMED AT TWO LEVELS, VIZ. MASTER CONTROL CENTRE (SCADA) AND UNIT CONTROL PANEL (UCP)/ COMMON FACILITY PANEL (FCP).
- VENDOR TO INDICATE UTILITY REQUIREMENT.
- NORMAL SEAL GAS SUPPLY SHALL BE FROM COMPRESSOR DISCHARGE, HOWEVER, PROVISION FOR START-UP/EMERGENCY SEAL GAS FROM LINE PACK OF EXISTING HBJ PIPELINE SHALL BE MADE. PROVISION FOR CHANGE OVER FROM NORMAL TO EMERGENCY SEAL GAS SUPPLY & VIS-A-VIS IS UNDER GTC VENDOR'S SCOPE. VENDOR TO PROVIDE FLOW INDICATION AND ALARM IN SEAL GAS SUPPLY LINE.
- VENDOR TO PROVIDE NECESSARY FILTER, ELECTRIC HEATER, PRESSURE REGULATOR, CONTROL VALVES ETC. FOR SEAL GAS SYSTEM.
- ACCESSORIES LIKE AFTERCOOLERS, INSTRUMENTATION AND CONTROL PANEL ARE IN VENDORS SCOPE OF SUPPLY.
- PSV ON COMPRESSOR DISCHARGE SHALL BE SET AT 104.17 KG/CM²G.
- DESIGN TEMPERATURE SPECIFIED IS FOR DOWNSTREAM OF AFTER COOLER.

Rev. No.	Date	Purpose	Prepared By	Reviewed By	Approved By
2	24.02.2009	REVISED AS MARKED	MKA	AS	AS
1	19.02.2009	REVISED AS PER CLIENT'S/ENGG. INPUTS	MKA	HKP	HKP
0	02.01.2009	ISSUED FOR COMMENTS/ENGINEERING	MKA	AS	AS

PROJECT	COMPRESSOR STATION WORKS AT KAILARAS & CHAINSA	CLIENT	GAIL
UNIT	CHAINSA COMPRESSOR STATION	JOB NO.	6988
ITEM NO.	071-KA-CF-101A/B/C	SERVICE	NATURAL GAS COMPRESSOR
		UNIT NO.	071

NOTES:

17 FUEL GAS SHALL BE TAKEN FROM COMPRESSOR INLET COMMON HEADER .

GAS COMPOSITION	COMPONENT	MOLE%	
		(RICH GAS)	(LEAN GAS, NOTE-28)
	METHANE	92.49	94.07
	ETHANE	5.64	4.59
	PROPANE	1.41	1.07
	I-BUTANE	0.2	0.18
	N-BUTANE	0.15	0.00
	N-PENTANE	0.01	0.00
	NITROGEN	0.09	0.09
	H2S	6 PPMW	6 PPMW
	TOTAL SULFUR	24 PPMW	24 PPMW
	TOTAL	100.0	100.00
	SUPPLY PRESSURE KG/CM2(G)	73.6	74.0
	SUPPLY TEMP. DEG. C	34.5	34.4
	LHV (KCAL/KG)=	11840	11860
	HC DEW POINT(DEG C)=	< -46.0	< -46.0
	AT SUCTION PRESSURE		

18 Cp/Cv VALUE IS ESTIMATED FOR CALCULATION PURPOSE.

19 NOTE - DELETED.

20 COMPRESSOR VENDOR TO FURNISH SETTLE OUT PSESSURE CALCULATION AND BLOW DOWN CALCULATIONS FOR REVIEW BY EIL.

21 FOR AFTER COOLER DATA SHEET, REFER DOC. NO. 6988-071-02-DS-1401

22 VENDOR TO PROVIDE MAX. RATE OF DEPRESSURISATION DURING COMPRESSOR TRIP/ESD.

23 DISCHARGE PRESSURE INDICATED IS AT THE COMPRESSOR DISCHARGE FLANGE.

24 NECESSARY PROVISION SHALL BE KEPT FOR WASTE HEAT RECOVERY FROM GT EXHAUST IN FUTURE.

25 VENDOR TO INDICATE NITROGEN REQUIREMENT FOR EACH COMPRESSOR.

26 INDICATED IS MINIMUM RATING. VENDOR TO CHECK AND CONFIRM THE SAME.

27 VENDOR TO COMPUTE DESIGN TEMPERATURE AT COMPRESSOR DISCHARGE FLANGE BASED ON THE GOVERNING CASE OF HIGHEST DISCHARGE TEMPERATURE.

28 COMPOSITION CONSIDERED AFTER C2 / C3 RECOVERY FROM EXISTING RLNG SUPPLY OF 12 MMSCMD FROM PLL.

29 START UP/ EMERGENCY SEAL GAS SUPPLY FROM EXISTING LINE PACK OF GREP PIPELINE IS CHARACTERIZED AS BELOW.

COMPONENTS	H2O	N2	CO2	H2S	C1	C2	C3	I-C4	N-C4	I-C5	N-C5	C6	C7	MOL. WT.
RLNG-HP LEAN GAS EX LPG MOL %	NIL	0.13	1.4	NIL	91.80	2.34	4.07	0.14	0.1	0	0	0.00	0	18
PRESSURE	HOLD KG/CM2 G.				DEW POINT HOLD									
TEMPERATURE	HOLD KG/CM2 G.													

30 DEW POINT OF NORMAL SEAL GAS SUPPLY SHALL BE AS INDICATED IN NOTE-17

31 NOTE -DELETED

Rev. No.	Date	Purpose	Prepared By	Reviewed By	Approved By
2	24.02.2009	REVISED AS MARKED	MKA	AS	AS
1	19.02.2009	REVISED AS PER CLIENT'S/ENGG. INPUTS	MKA	HKP	HKP
0	02.01.2009	ISSUED FOR COMMENTS/ENGINEERING	MKA	AS	AS



ENGINEERS INDIA LIMITED
NEW DELHI

6988 ITEM NO.

R-R proposal no. OG1331

R
E
V

CENTRIFUGAL COMPRESSOR
DATA SHEET (API 617-6TH)
SI UNITS

REVISION NO. 0 DATE 6-Apr-08
PAGE 1 OF 6 BY J. Bygrave

1 APPLICABLE TO: PROPOSAL PURCHASE AS BUILT

2 FOR EIL - GAIL PIPELINE EXPANSION PROJECT UNIT _____

3 SITE Chainsa Station SERIAL NO. _____

4 SERVICE Gas Transmission NO. REQUIRED 2

5 CONTINUOUS INTERMITTENT STAND BY DRIVER TYPE (3.1.1) Gas Turbine

6 MANUFACTURER Rolls-Royce MODEL RFBB36 DRIVER ITEM NO. _____

7 NOTE: INFORMATION TO BE COMPLETED: BY PURCHASER BY MANUFACTURER

OPERATING CONDITIONS

(ALL DATA ON PER UNIT BASIS)

OTHER CONDITIONS (3.1.2)

13 GAS HANDLED (ALSO SEE PAGE 2)

14 nm³/h (1.013 BAR & 0 °C)

15 WEIGHT FLOW, kg/min

16 **INLET CONDITIONS**

17 PRESSURE (kg/cm²g)

18 TEMPERATURE (°C)

19 RELATIVE HUMIDITY %

20 MOLECULAR WEIGHT (Mw)

21 Cp/Cv (K_{AVG})

22 COMPRESSIBILITY

23 INLET VOLUME, (m³/s)

24 **DISCHARGE CONDITIONS**

25 PRESSURE (kg/cm²g)

26 TEMPERATURE (°C)

27 Cp/Cv (K_{AVG})

28 COMPRESSIBILITY

29 FRICTION POWER (KW)

30 KW REQUIRED (ALL LOSSES INCLUDED)

31 SPEED (RPM)

32 ESTIMATED SURGE RANGE, % (AT SPEED ABOVE)

33 POLYTROPIC HEAD (kJ/kg)

34 POLYTROPIC EFFICIENCY (%)

35 CERTIFIED POINT

36 PERFORMANCE CURVE NUMBER

37 **PROCESS CONTROL**

38 METHOD SUCTION THROTTLING VARIABLE INLET SPEED VARIATION DISCHARGE COOLED BYPASS

39 FROM _____ (BAR)(kPa abs) GUIDE VANES FROM 70 % BLOWOFF FROM Discharge

40 TO _____ (BAR)(kPa abs) (3.4.2.4) TO 105 % TO _____ TO Suction

42 SIGNAL SOURCE (3.4.2.1) Suction / Discharge Pressure, Flow

43 TYPE ELECTRONIC PNEUMATIC OTHER _____

44 RANGE 4 - 20 MA _____ (BAR)(kPa abs) _____

46 ANTI-SURGE BYPASS MANUAL AUTOMATIC NONE

48 REMARKS:

49

50



ENGINEERS INDIA LIMITED
NEW DELHI

JOB NO. 6988 ITEM NO. _____
 REVISION NO. 0 DATE 6-Apr-08
 PAGE 2 OF 6 BY J. Bygrave

R
E
V

CENTRIFUGAL COMPRESSOR
DATA SHEET (API 617-6TH)
SI UNITS

OPERATING CONDITIONS (Continued) (3.1.2) (3.1.3)									
GAS ANALYSIS:		NORMAL	OTHER CONDITIONS					REMARKS:	
<input type="radio"/> MOL % <input type="radio"/>			A	B	C	D	E		
	MW			Rich	Lean			(2.11.1.3) (2.11.1.8)	
5	AIR	28.966							
6	OXYGEN	32.000							
7	NITROGEN	28.016		0.09	0.09				
8	WATER VAPOR	18.016		NIL	NIL				
9	CARBON MONOXIDE	28.010							
10	CARBON DIOXIDE	44.010							
11	HYDROGEN SULFIDE	34.076		6 PPMW	6 PPMW			(2.11.1.7)	
12	HYDROGEN	2.016							
13	METHANE	16.042		92.49	94.07				
14	ETHYLENE	28.052							
15	ETHANE	30.068		5.64	4.59				
16	PROPYLENE	42.078							
17	PROPANE	44.094		1.41	1.07				
18	I-BUTANE	58.120		0.20	0.18				
19	n-BUTANE	58.120		0.15					
20	I-PENTANE	72.146							
21	n-PENTANE	72.146		0.01					
22	HEXANE PLUS								
23	TOTAL SULPHUR			24 PPMW	24 PPMW				
24									
25	TOTAL			99.99	100.00				
26	AVG. MOL. WT.			17.4	17.07				
27	LOCATION: (2.1.9)				NOISE SPECIFICATIONS: (2.1.10)				
28	<input type="radio"/> INDOOR <input checked="" type="radio"/> OUTDOOR <input type="radio"/> GRADE				<input type="radio"/> APPLICABLE TO MACHINE:				
29	<input type="radio"/> HEATED <input checked="" type="radio"/> UNDER ROOF <input type="radio"/> MEZZANINE				SEE SPECIFICATION _____				
30	<input checked="" type="radio"/> UNHEATED <input type="radio"/> PARTIAL SIDES <input type="radio"/> _____				<input type="radio"/> APPLICABLE TO NEIGHBORHOOD:				
31	<input checked="" type="radio"/> ELEC. AREA CLASSIFICATION (2.1.15) _____				SEE SPECIFICATION _____				
32	<input type="radio"/> WINTERIZATION REQ'D. (2.1.9) <input checked="" type="radio"/> TROPICALIZATION REQ'D. (3.4.6.6)				ACOUSTIC HOUSING: <input type="radio"/> YES <input checked="" type="radio"/> NO				
33	SITE DATA:				SOUND LEVEL <u>See Note</u> dB (A) @ _____ M				
34	<input checked="" type="radio"/> ELEVATION <u>197.8</u> m BAROMETER _____ BAR				APPLICABLE SPECIFICATIONS:				
35	<input type="radio"/> RANGE OF \pm 0.3				API 617, CENTRIFUGAL COMPR. FOR GEN. REFINERY SERV.				
36					<input checked="" type="radio"/> VENDOR HAVING UNIT RESPONSIBILITY (2.9.1.7)				
37	NORMAL °C <u>45 / 85%RH</u>				<input type="radio"/> GOVERNING SPECIFICATION (IF DIFFERENT)				
38	MAXIMUM °C <u>45 / 84%RH</u>								
39	MINIMUM °C <u>0 / 37%RH</u>								
40	_____ °C _____								
41	UNUSUAL CONDITIONS: <input checked="" type="radio"/> DUST <input type="radio"/> FUMES				PAINTING:				
42	<input checked="" type="radio"/> OTHER (2.1.9) _____				<input checked="" type="radio"/> MANUFACTURER'S STD.				
43	_____				<input type="radio"/> OTHER _____				
44	_____				SHIPMENT: (4.4.1)				
45	REMARKS: Noise level, for the compressor package in				<input type="radio"/> DOMESTIC <input type="radio"/> EXPORT <input checked="" type="radio"/> EXPORT BOXING REQ'D.				
46	isolation, shall not exceed 88 dba at 1 meter.				<input checked="" type="radio"/> OUTDOOR STORAGE MORE THAN 6 MONTHS (4.4.1)				
47	_____				SPARE ROTOR ASSEMBLY PACKAGED FOR (4.4.3.10)				
48	_____				<input type="radio"/> HORIZONTAL STORAGE <input type="radio"/> VERTICAL STORAGE				
49	_____								
50	_____								



ENGINEERS INDIA LIMITED
NEW DELHI

R
E
V

CENTRIFUGAL COMPRESSOR
DATA SHEET (API 617-6TH)
SI UNITS

JOB NO. 6988 ITEM NO. _____
REVISION NO. 0 DATE 6-Apr-08
PAGE 3 OF 6 BY J. Bygrave

CONSTRUCTION FEATURES

1
2 **SPEEDS:**
3 MAX. CONT. 5093 RPM TRIP 5350 RPM
4 MAX. TIP SPEEDS: 194.7 m/s @ 100% SPEED
5 204.4 m/s @ MAX. CONT. SPEED
6 **LATERAL CRITICAL SPEEDS (DAMPED)**
7 FIRST CRITICAL 2800 RPM 1st Brg MODE
8 SECOND CRITICAL ~7100 RPM 2nd Brg MODE
9 THIRD CRITICAL ~10600 RPM 1st Bendg MODE
10 FOURTH CRITICAL _____ RPM _____ MODE
11 LATERAL ANALYSIS REQUIRED (2.9.2.3)
12 TRAIN TORSIONAL ANALYSIS REQUIRED
13 (TURBINE DRIVEN TRAIN) (2.9.4.5)
14 **TORSIONAL CRITICAL SPEEDS:**
15 FIRST CRITICAL Per API 617 RPM
16 SECOND CRITICAL Per API 617 RPM
17 THIRD CRITICAL Per API 617 RPM
18 FOURTH CRITICAL Per API 617 RPM
19 **VIBRATION:** Std test limit 39.0 µm, RR to attempt
20 ALLOWABLE TEST LEVEL 25 µm with reasonable effort to
21 (PEAK TO PEAK) obtain
22 **ROTATION, VIEWED FROM DRIVEN END** CW CCW
23 **MATERIALS INSPECTION REQUIREMENTS (4.2.2)**
24 SPECIAL CHARPY TESTING (2.11.3)
25 RADIOGRAPHY REQUIRED FOR _____ per specification
26 ULTRASONIC REQUIRED FOR _____ plus R-R clarifications
27 MAGNETIC PARTICLE REQUIRED FOR _____ Shaft, Impellers
28 LIQUID PENETRANT REQUIRED FOR _____ Guide vanes
29 **CASING:**
30 MODEL RFBB36
31 CASING SPLIT Vertical
32 MATERIAL CASE & COVER A-34 or A-55 CAST STEEL
33 THICKNESS (mm) 76 CORR. ALLOW. (mm) 3.2
34 MAX. WORKING PRESS 150 (BARG)
35 MAX DESIGN PRESS 155 (BARG)
36 TEST PRESS (BARG): HELIUM HYDRO 1.5x MWP
37 MAX OPER. TEMP. 177 °C MIN. OPER. TEMP. -35 °C
38 MAX NO. OF IMPELLERS FOR CASING 4-5 depends on Appl
39 MAX CASING CAPACITY (m³/h) 90000
40 CASING SPLIT SEALING (2.2.10) O-ring
41 SYSTEM RELIEF VALVE SET PT. (2.2.4) _____ (MPaG)(assumed)
42 **DIAPHRAGMS:**
43 MATERIAL Stl ASTM A36; Gray Iron ASTM A48 CI 40C
44 **IMPELLERS:**
45 NO. 2 DIAMETERS 766.65
46 NO. VANES EA. IMPELLER 17 (prel)
47
48 **REMARKS** Materials are all RR standard, with years of experience.
49 Operating Temperature limits are for normal service-Maximum
50 operating temperature may be modified during detail design
51 Barrier seal plus separation air system is also included.

TYPE (OPEN, ENCLOSED, ETC.) Enclosed
TYPE FABRICATION Welded
MATERIAL Stl Forging, USS T-1, Type C
MAX. YIELD STRENGTH (N) 620
BRINNEL HARDNESS: MAX 293 MIN 248
SMALLEST TIP INTERNAL WIDTH (mm) After design
MAX. MACH. NO. @ IMPELLER EYE After Design
MAX. IMPELLER HEAD @ 100% SPD (N-m/kg) _____
SHAFT:
MATERIAL Stl Forging, ASTM A-668 Cl.L
DIA @ IMPELLERS (mm) 215.9 DIA @ COUPLING (mm) 165.1
SHAFT END: TAPERED CYLINDRICAL
MAX. YIELD STRENGTH (N) 930
SHAFT HARDNESS (BNH)(Rc) 331 BNH Max
SHAFT HARDNESS (BNH)(Rc) 269 BNH Min
BALANCE PISTON:
MATERIAL Stl Plate ASTM A-514.Gr.F/Q AREA Later (mm²)
FIXATION METHOD Shrink Fit + 2 keys
SHAFT SLEEVES : N / A
AT INTERSTG. CLOSE MATL _____
CLEARANCE POINTS
AT SHAFT SEALS MATL _____
 ACCESSIBLE (2.8.2)
LABYRINTHS:
INTERSTAGE
TYPE Renewable MATERIAL Alum AA Alloy 771 T-5
BALANCE PISTON
TYPE Honeycomb MATERIAL SST ASTM A240
Type 321
SHAFT SEALS:
 SEAL TYPE (2.8.3) Tandem Dry Gas Face Seals
 SETTLING OUT PRESSURE (BARG) TBD
 SPECIAL OPERATION (2.8.1)
 SUPPLEMENTAL DEVICE REQUIRED FOR CONTACT
SEALS (2.8.3.2) TYPE _____
 BUFFER GAS SYSTEM REQUIRED (2.8.7) MANIFOLD (3.5.1.6)
 TYPE BUFFER GAS Pri:Filt Process Gas; Sec: N2; Barrier: Air
 BUFFER GAS CONTROL SYSTEM SCHEMATIC BY VENDOR
 PRESSURIZING GAS FOR SUBATMOSPHERIC SEALS (2.8.8)
 TYPE SEAL Burgmann PDGS intermed laby, intchgble NDE-DE
 INNER OIL LEAKAGE GUAR. (λ /DAY/SEAL) N / A
BUFFER GAS REQUIRED FOR:
 AIR RUN-IN OTHER N2 for run-in
BUFFER GAS FLOW (PER SEAL):
NORM: 7.1 am³/h @ Design (kPa) Δ P 50
MAX. 10.7 am³/h @ Design (kPa) Δ P 100
BEARING HOUSING CONSTRUCTION:
TYPE (SEPARATE, INTEGRAL) Separate SPLIT Vertical
MATERIAL Stl ASTM A668 Cl B; Iron ASTM A48 Cl 40C



ENGINEERS INDIA LIMITED
NEW DELHI

JOB NO. 6988 ITEM NO. _____
 REVISION NO. 0 DATE 6-Apr-08
 PAGE 4 OF 6 BY J. Bygrave

R
E
V

CENTRIFUGAL COMPRESSOR
DATA SHEET (API 617-6TH)
SI UNITS

CONSTRUCTION FEATURES (CONTINUED)

BEARINGS AND BEARING HOUSINGS

RADIAL		INLET	EXHAUST	THRUST		ACTIVE	INACTIVE
<input checked="" type="checkbox"/> TYPE	Tilt-Pad	Tilt-Pad	<input checked="" type="checkbox"/> TYPE	Self Leveling/Tilting Pad		Waukesha	
<input checked="" type="checkbox"/> MANUFACTURER	Waukesha		<input checked="" type="checkbox"/> MANUFACTURER	Waukesha		After Design	
<input checked="" type="checkbox"/> LENGTH (mm)	82.6	82.6	<input checked="" type="checkbox"/> UNIT LOADING (MAX BAR)	After Design	After Design	44.83	
<input checked="" type="checkbox"/> SHAFT DIA. (mm)	165.1	165.1	<input checked="" type="checkbox"/> UNIT LOAD (ULT.) (BAR)	33226	33226	9	
<input checked="" type="checkbox"/> UNIT LOAD (ACT/ALLOW) (Bar)	<5 / 15	<5 / 15	<input checked="" type="checkbox"/> AREA (mm ²)	9	9	Offset 70%	
<input checked="" type="checkbox"/> BASE MATERIAL	Steel	Steel	<input checked="" type="checkbox"/> NO. PADS	Offset 70%	Offset 70%	Stl / Tin based Babbitt	
<input checked="" type="checkbox"/> BABBIT THICKNESS (mm)	Tin Based > 1.5		<input checked="" type="checkbox"/> PIVOT: CENTER / OFFSET, %	LUBRICATION: <input checked="" type="radio"/> FLOODED <input type="radio"/> DIRECTED			
<input checked="" type="checkbox"/> NO. PADS	4	4	<input checked="" type="checkbox"/> PAD BASE MATL	THRUST COLLAR: <input type="radio"/> INTEGRAL <input checked="" type="radio"/> REPLACEABLE			
<input checked="" type="checkbox"/> LOAD: B'TWN/ON PAD	Between	Between		MATERIAL <u>Steel Plate AISI 4340</u>			
<input checked="" type="checkbox"/> PIVOT: CTR/OFFSET, %	Center	Center					

BEARING SPAN 2263 mm

BEARING TEMPERATURE DEVICES SEE ATTACHED API-670 DATA SHT

THERMISTORS

TYPE POS TEMP COEFF NEG TEMP COEFF

TEMP SWITCH & INDICATOR BY: PURCH MFR

THERMOCOUPLES

SELECTOR SWITCH & INDIC. BY: PURCH MFR

RESISTANCE TEMP DETECTORS

RESISTANCE MAT'L Platinum 100 OHMS

SELECTOR SWITCH & INDICATOR BY: PURCH X MFR

LOCATION-JOURNAL BRG

NO. EA PAD EVERY OTH PAD 2 PER BRG

OTHER

LOCATION-THRUST BRG

NO. EA PAD EVERY OTH PAD 2 PER BRG

OTHER

NO. (INACT) EA PAD EVERY OTH PAD 2 PER BRG

OTHER

MONITOR SUPPLIED BY (3.4.7.4) Rolls-Royce

LOCATION UCP ENCLOSURE

MFR. Rolls-Royce MODEL 3500

SCALE RGE ALARM SET @ 120 °C

SHTDWN SET @ 130 °C TIME DELAY 1 SEC

SEE ATTACHED API-670 DATA SHEET

VIBRATION DETECTORS:

TYPE Non-Contacting MODEL 3300 XL

MFR Bently-Nevada

NO. AT EA SHAFT BEARING 2 TOTAL NO. 4

OSCILLATOR-DETECTORS SUPPLIED BY Rolls-Royce

MFR Bently-Nevada MODEL 3300 XL

MONITOR SUPPLIED BY (3.4.7.2)

LOCATION UCP ENCLOSURE

MFR. Bently-Nevada MODEL 3500

SCALE RGE ALARM SET @ 60 um

SHTDWN: SET @ 90 um TIME DELAY 1 SEC

SEE ATTACH. API-670 DATA SHEET

AXIAL POSITION DETECTOR:

TYPE Non-Contacting MODEL 3300 XL

MFR Bently-Nevada NO. REQUIRED 2

OSCILLATOR-DEMODULATOR SUPPLIED BY Rolls-Royce

MFR Bently-Nevada MODEL 3300 XL

MONITOR SUPPLIED BY (3.4.7.2) Rolls-Royce

LOCATION UCP ENCLOSURE

MFR. Bently-Nevada MODEL 3500

SCALE RGE ALARM SET @ +/- .5 um

SHTDWN: SET @ +/- .65 um TIME DELAY 1 SEC

CASING CONNECTIONS

CONNECTION	<input checked="" type="checkbox"/> DESIGN APPROVAL REQ'D (2.11.2.10)	<input type="checkbox"/> ASME <input type="checkbox"/> API605 <input type="checkbox"/> OTHERS SIZE	<input checked="" type="checkbox"/> FACING	POSITION (2.4.2.1)	FLANGED OR STUDDED (2.4.2.1)	MATING FLG & GASKET BY VENDOR (2.4.2.3)	GAS VELOCITY m/SEC
INLET	No	914.4mm 900#	RF	Horiz/Side	Flanged	Yes	14.50
DISCHARGE	No	914.4mm 900#	RF	Horiz/Side	Flanged	Yes	11.99

REMARKS

Dimensions indicated (diameters and lengths) are typical for normal service - actual dimensions are subject to design review

Vibration and position detector settings are typical

Axial position alarm and shutdown setting is equal to the measured thrust bearing axial clearance plus the indicated value.



ENGINEERS INDIA LIMITED
NEW DELHI

R
E
V

CENTRIFUGAL COMPRESSOR
DATA SHEET (API 617-6TH)
SI UNITS

JOB NO. 6988 ITEM NO. _____
REVISION NO. 0 DATE 6-Apr-08
PAGE 5 OF 6 BY J. Bygrave

OTHER CONNECTIONS			
SERVICE:	NO.	SIZE	TYPE
LUBE-OIL INLET	2	1"1"	NPTF/3000#SAE
LUBE OIL OUTLET	4	1"-2"	3000#SAE
SEAL-OIL INLET			
SEAL-OIL OUTLET			
SEAL GAS INLET	2	.75"	3000# SAE
SEAL GAS OUTLET	2	.75"	3000# SAE
CASING DRAINS	2	.75"	3000# SAE
STAGE DRAINS			
VENTS	2	.75"-2"	3000# SAE
VENTS			
PRESSURE	4	1"	NPTF, 2 each nozz
TEMPERATURE	8	1"	NPTF, 4 each nozz
SOLVENT INJECTION			
PURGE FOR:			
BRG. HOUSING			
BTWN BRG & SEAL	2	.75"	3000# SAE
BTWN SEAL & GAS	2	.75"	3000# SAE

INDIVIDUAL STAGE DRAINS REQUIRED (2.4.3.2)
 VALVED & BLINDED
 VALVED & BLINDED & MANIFOLD 2 Casing drains
 KEY PHASOR REQUIRED
 COMPRESSOR GEAR DRIVER

ALLOWABLE PIPING FORCES AND MOMENTS:

INLET		DISCHARGE			
FORCE	MOMT	FORCE	MOMT	FORCE	MOMT
N	N-m	N	N-m	N	N-m
AXIAL VERTICAL HORIZ. 90 Per Rolls-Royce Standard GER 0123 para 3.2, ref Fig 4 & Table 7b					
Per Rolls-Royce Standard GER 0123 para 3.2, ref Fig 4 & Table 7b					

- ACCELEROMETER(3.4.7.5) N/A
- SEE ATTACHED API-670 DATA SHEET
- TYPE _____ MODEL _____
- MFR _____ NO. REQUIRED _____
- LOCATION _____
- OSCILATOR-DEMODULATORS SUPPLIED BY
- MFR _____ MODEL _____
- MONITOR SUPPLIED BY (3.4.7.6)
- LOCATION _____ ENCLOSURE _____
- MFR _____ MODEL _____
- SCALE RANGE _____ ALARM SET @ _____ mm/SEC²
- SHTDWN SET @ _____ mm/SEC² TIME DELAY _____ SEC

ACCESSORIES

COUPLING AND GUARDS (3.2)
 NOTE: SEE ROTATING ELEMENTS - SHAFT ENDS
 SEE ATTACHED API-671 DATA SHEET KEYLESS HYDRAULIC KEYED
 COUPLING FURNISHED BY Rolls-Royce
 MANUFACTURER Bibby or equal TYPE Dry MODEL service factor ≥ 1.75
 COUPLING GUARD FURNISHED BY: Rolls-Royce
 TYPE: FULLY ENCLOSED SEMI-OPEN OTHER non-sparking

COUPLING DETAILS (PREL)

MAX O.D.	427	mm
HUB WEIGHT	46	kg
SPACER LENGTH	1524 (1524 DBSE)	mm
SPACER WEIGHT	163	kg

VENDOR MOUNT HALF COUPLING
 LUBRICATION REQUIREMENTS:
 NON-LUBE GREASE CONT. OIL LUBE OTHER
 QUANTITY PER HUB _____ kgs or L/MIN

MOUNTING PLATES
 BASEPLATES: FURNISHED BY (3.3.1.1)
 COMPRESSOR ONLY (3.3.2.1) DRIVER GEAR
 OTHER _____
 DRIP TRIM LEVELING PADS (3.3.2.2)
 COLUMN MOUNTING (3.3.2.3)
 SUB-SOLE PLATES REQ'D (3.3.3.2)
 STAINLESS STEEL SHIM THICKNESS _____ mm
 PRIMER FOR EPOXY GROUT REQ'D (3.3.1.2.9)
 TYPE _____
 BASE PLATE WILL BE ON CONCRETE FOUNDATION (3.3.2.5)
 MACHINED MOUNTING PADS REQ'D. (3.3.2.6)

SOLEPLATES: FURNISHED BY: Rolls-Royce
 THICKNESS _____ mm
 SUBSOLE PLATES REQ'D (3.3.3.2)
 STAINLESS STEEL SHIM THICKNESS - mm
 DRIVER _____ GEAR _____ COMPRESSOR 3.2 mm
 PRIMER FOR EPOXY GROUT REQ'D (3.3.1.2.9)
 TYPE _____

REMARKS
 Number and size of connections is preliminary
 Final quantity and location will be advised after final design
 is complete.
 Foundation bolts by Rolls-Royce



ENGINEERS INDIA LIMITED
NEW DELHI

R
E
V

CENTRIFUGAL COMPRESSOR
DATA SHEET (API 617-6TH)
SI UNITS

JOB NO. 6988 ITEM NO. _____
REVISION NO. 0 DATE 6-Apr-08
PAGE 6 OF 6 BY J. Bygrave

UTILITIES

● **UTILITY CONDITIONS:** (see R-R proposal)

STEAM:	N / A	DRIVERS	HEATING
INLET MIN	_____	BARG(kPaG) _____ °C	BARG(kPaG) _____ °C
NORM	_____	BARG(kPaG) _____ °C	BARG(kPaG) _____ °C
MAX	_____	BARG(kPaG) _____ °C	BARG(kPaG) _____ °C
EXHAUST. MIN	_____	BARG(kPaG) _____ °C	BARG(kPaG) _____ °C
NORM	_____	BARG(kPaG) _____ °C	BARG(kPaG) _____ °C
MAX	_____	BARG(kPaG) _____ °C	BARG(kPaG) _____ °C

ELECTRICITY: (3.4.6.1)

	DRIVERS	HEATING	CONTROL	SHUTDOWN
VOLTAGE	_____	_____	_____	_____
HERTZ	_____	_____	_____	_____
PHASE	_____	_____	_____	_____

COOLING WATER: N / A

TEMP. INLET	_____ °C	MAX RETURN	_____ °C
PRESS NORM	_____ BARG(kPaG)		
DESIGN	_____ BARG(kPaG)		
MIN RETURN	_____ BARG(kPaG)		
MAX ALLOW Δ P	_____ BAR(kPa)		

WATER SOURCE _____

INSTRUMENT AIR:

MAX PRESS _____ BARG(kPaG) MIN PRESS _____ BARG(kPaG)

■ **TOTAL UTILITY CONSUMPTION:**

COOLING WATER	N / A	m ³ /h
STEAM, NORMAL	N / A	kg/h
STEAM, MAX	N / A	kg/h
INSTRUMENT AIR	Separation seal air - 20	m ³ /h
HP (DRIVER)	See compressor performance	kW
HP (AUXILIARIES)	See P&ID's	kW
HEATERS	See P&ID's	KW
PURGE (AIR OR N ₂)	Only required for initial start-up	m ³ /h

- MISCELLANEOUS:** per RR standards
- **RECOMMENDED STRAIGHT RUN OF PIPE DIAMETERS**
BEFORE SUCTION **Minimum of 3**
 - NOMOGRAPHS REQUIRED FOR EACH SECTION (5.3.3.1.5)
 - **VENDOR'S REVIEW & COMMENTS ON PURCHASER'S PIPING & FOUNDATION (3.5.3.2)** Scope/Responsibility to be agreed pre-order
 - COMPRESSOR TO BE SUITABLE FOR FIELD RUN IN ON AIR (2.1.17)
 - PROVISION FOR LIQUID INJECTION (2.1.11)
 - **VENDOR'S REVIEW & COMMENTS ON PURCHASER'S CONTROL SYSTEMS (3.4.1.1)**
 - EXTENT OF PROCESS PIPING BY VENDOR (3.5.3.1)
 - SHOP FITUP OF VENDOR PROCESS PIPING (4.4.3.11)
 - **WELDING HARDNESS TESTING (4.2.1.6)**
 - _____
 - **VENDOR'S REPRESENTATIVE SHALL (2.1.14)**
 - OBSERVE FLANGE PARTING
 - CHECK ALIGNMENT AT TEMPERATURE
 - BE PRESENT AT INITIAL ALIGNMENT

SHOP INSPECTION AND TESTS: (4.1.4)

	REQ'D.	WITN
25 CLEANLINES (4.2.1.5)	●	●
26 HYDROSTATIC	●	●
27 IMPELLER OVERSPEED	●	●
28 MECHANICAL RUN	●	●
29 ● CONTRACT COUPLING ○ IDLING ADAPTORS		
30 ● CONTRACT PROBES ○ SHOP PROBES		
31 VARY LUBE & SEAL OIL PRESSURES	●	●
32 AND TEMPERATURES (4.3.4.2.5) within allowable limits		
33 POLAR FORM VIB DATA (4.3.4.3.3) Bode plot in polar form	●	●
34 VIBRATION DATA RECORDED (4.3.4.3.6) Adre digital data	●	●
35 DATA TO PURCHASER (4.3.4.3.7) Adre data via CD	●	●
36 SHAFT END SEAL INSP (4.3.4.4.1)	●	●
37 GAS LEAK TEST DISCH PRESS (4.3.5.2)	●	●
38 ○ BEFORE ● AFTER POST TEST INSPECTION (4.3.6.8)		
39 PERFORMANCE TEST(GAS)(PTC10 TYPE II)(4.3.6.1)	●	●
40 NO LOAD STRING TEST (4.3.6.2) (ONE PER STATION)	●	●
41 DIS-ASSEMBLE/RE-ASSEMBLE AFTER TEST (REM-7)	●	●
42 DYNAMIC BALANCING OF ROTOR W/O HALF COUPLING	●	Obs
43 GEAR TEST (4.3.6.4)	○	
44 HELIUM LEAK TEST	○	
45 SOUND LEVEL SURVEY DURING STRING TEST	●	●
46 SHOP VERIFICATION OF UNBALANCED RESPONSE	●	●
47 ANALYSIS (@ COUPLING HUB ONLY) (ONE PER STATION)		
48 COPIES OF CERTIFIED TEST DATA & MATERIALS	●	
49 RESIDUAL ELECT. & MECH RUN OUT	●	●
50 CHECK BEARINGS & SEALS AFTER TEST (REM-7)	●	●
51	●	●

■ **WEIGHTS (kg):**

COMPR.	46500	GEAR	_____	DRIVER	_____	BASE	_____
ROTORS:	COMPR.	1125	DRIVER	_____	GEAR	_____	_____
COMPRESSOR COVER							5500
SOUR SEAL OIL TRAPS							N/A
L.O. CONSOLE							S.O. CONSOLE
OVERHEAD SEAL OIL TANKS							N/A
MAX. FOR MAINTENANCE (IDENTIFY)							Aero and Rotor 10100
TOTAL SHIPPING WEIGHT							Compressor + Pipe and Elect 49500


■ **SPACE REQUIREMENTS (mm):** (See R-R Proposal)

COMPLETE UNIT:	L	_____	W	_____	H	_____
L.O. CONSOLE:	L	_____	W	_____	H	_____
S.O. CONSOLE:	L	_____	W	_____	H	_____
SOUR SEAL OIL TRAPS						
OVERHEAD SEAL OIL TANKS						


SEE INSTALLATION SECTION OF PROPOSAL

- REMARKS:**
- 5) Spare rotor will receive mech run test
 - 6) No load string test shall be carried out for one GTC package per station
 - 7) Post test inspection of the dry gas seal and bearing shall be carried during the spare rotor changeout only. DGS inspection as per Burgmann instructions


GAIL Pipeline Expansion Project Feb 24'09
RF36-2 MW 17.393 Pd 99.930 kG/cm².g TI 34.50 °C



GAIL Pipeline Expansion Project Feb 24'09
RF36-2 MW 17.393 PI 74.100 kg/cm².g TI 34.50 °C



GAIL Pipeline Expansion Project Feb 24'09
RF36-2 MW 17.393 Pd 99.930 kG/cm².g TI 34.50 °C




CompPerform[1.79]
PLAN: Chai nsa

UNIT SPECIFIED

SECTION 1

GAIL Pipeline Expansion Project Feb 24'09
RF36-2 MW 17.074 Pd 99.930 kg/cm².g TI 34.40 °C




3.000
CompPerform[1.79]
PLAN: Chai nsa


UNIT SPECIFIED


SECTION 1


GAIL Pipeline Expansion Project Feb 24'09
RF36-2 MW 17.074 PI 74.500 kg/cm².g TI 34.40 °C



GAIL Pipeline Expansion Project Feb 24'09
RF36-2 MW 17.074 Pd 99.930 kG/cm².g TI 34.40 °C



 ENGINEERS INDIA LIMITED NEW DELHI	JOB NO. <u>6988</u> ITEM NO. _____ PURCHASE ORDER NO. _____ SPECIFICATION NO <u>6988-000-KA-MR-5010</u> REVISION NO. <u>0</u> DATE <u>5-Apr-09</u> PAGE <u>1</u> OF <u>10</u> BY <u>Leong, HT</u>	R E V																																																																																					
COMBUSTION GAS TURBINE (API 616-4TH) DATA SHEET SI UNITS																																																																																							
1 APPLICABLE TO: <input checked="" type="radio"/> PROPOSAL <input type="radio"/> PURCHASE <input type="radio"/> AS BUILT 2 FOR <u>GAIL (INDIA) LIMITED</u> UNIT <u>PIPELINE EXPANSION PROJECT</u> 3 SITE <u>CHAINSA STATION</u> SERIAL NO. _____ 4 SERVICE <u>GAS COMPRESSOR</u> NO. REQUIRED <u>TWO (2)</u> 5 <input checked="" type="radio"/> CONTINUOUS <input type="radio"/> INTERMITTENT <input type="radio"/> STANDBY DRIVEN EQUIP. <u>CENTRIFUGAL COMPRESSOR</u> 6 MANUFACTURER <u>Rolls-Royce</u> <input checked="" type="radio"/> MODEL <u>RB211-GT61 DLE</u> ISO RATING <u>32,987</u> kW @ <u>4850</u> RPM 7 NOTE: INFORMATION TO BE COMPLETED: <input type="radio"/> BY PURCHASER <input type="checkbox"/> BY MANUFACTURER <input checked="" type="checkbox"/> BY MFR IF NOT BY PURCHASER																																																																																							
GENERAL																																																																																							
9 CYCLE: <input type="radio"/> REGEN <input checked="" type="radio"/> SIMPLE <input type="radio"/> EXHAUST HEAT RECOVERY TYPE: <input type="checkbox"/> SINGLE SHAFT <input checked="" type="checkbox"/> MULTI SHAFT 10 DRIVEN EQUIPMENT: NORMAL SHAFT, kW @ _____ RPM RATED SHAFT (KW) _____ @ _____ RPM 11 OUTPUT SHAFT SPEED RANGE (4.1.5) <input checked="" type="checkbox"/> MIN <u>3152</u> <input checked="" type="checkbox"/> MAX <u>5090</u> RPM 12 DESIRED MINIMUM SITE POWER _____ kW @ _____ RPM <input checked="" type="radio"/> ENCLOSURE REQUIRED 13 OPERATION <input checked="" type="radio"/> ATTENDED <input type="radio"/> UNATTENDED <input type="checkbox"/> POTENTIAL MAXIMUM POWER (3.33) _____ Kw																																																																																							
PERFORMANCE		LOCATION (4.1.19)																																																																																					
15 GAS TURBINE INCLUDING ALL LOSSES <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">SITE RATED (3.45)</th> <th style="text-align: center;">NORMAL DUTY (3.26)</th> <th style="text-align: center;">SITE MAX TEMP</th> <th style="text-align: center;">SITE MIN TEMP</th> </tr> </thead> <tbody> <tr> <td>19 <input checked="" type="radio"/> DRY BULB TEMP, °C</td> <td style="text-align: center;">45</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">45</td> <td style="text-align: center;">0</td> </tr> <tr> <td>20 <input checked="" type="radio"/> RELATIVE HUMIDITY %</td> <td style="text-align: center;">84</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">84</td> <td style="text-align: center;">37</td> </tr> <tr> <td>21 <input checked="" type="radio"/> ALTITUDE (m)</td> <td style="text-align: center;">197.8</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">197.8</td> <td style="text-align: center;">197.8</td> </tr> <tr> <td>22 <input type="checkbox"/> OUTPUT, (KW) (1)</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>23 <input type="checkbox"/> HEAT RATE, LHV, MJ/ KW-HR</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>24 <input checked="" type="checkbox"/> OUTPUT SHAFT SPEED, RPM</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>26 <input type="checkbox"/> AIR FLOW kg/SEC</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>27 <input type="checkbox"/> EXHAUST FLOW kg/SEC (1)</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>28 <input type="checkbox"/> FIRING TEMPERATURE °C</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>29 <input type="checkbox"/> GAS GEN. EXHAUST TEMP °C</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>30 <input type="checkbox"/> PT EXHAUST TEMP. °C</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>31 <input checked="" type="radio"/> CERTIFIED POINT (3.26)</td> <td style="text-align: center;">YES</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>32 (1) INCLUDING <input type="radio"/> STEAM <input type="radio"/> WATER EFFECTS FOR</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>33 <input checked="" type="checkbox"/> EMISSION CONTROL <input checked="" type="checkbox"/> AUGMENTATION (4.1.9)</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>34 <input type="checkbox"/> STEAM FLOW, kg/HR</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> <tr> <td>35 <input type="checkbox"/> WATER FLOW, m³/HR</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> <td style="text-align: center;">_____</td> </tr> </tbody> </table>			SITE RATED (3.45)	NORMAL DUTY (3.26)	SITE MAX TEMP	SITE MIN TEMP	19 <input checked="" type="radio"/> DRY BULB TEMP, °C	45	_____	45	0	20 <input checked="" type="radio"/> RELATIVE HUMIDITY %	84	_____	84	37	21 <input checked="" type="radio"/> ALTITUDE (m)	197.8	_____	197.8	197.8	22 <input type="checkbox"/> OUTPUT, (KW) (1)	_____	_____	_____	_____	23 <input type="checkbox"/> HEAT RATE, LHV, MJ/ KW-HR	_____	_____	_____	_____	24 <input checked="" type="checkbox"/> OUTPUT SHAFT SPEED, RPM	_____	_____	_____	_____	26 <input type="checkbox"/> AIR FLOW kg/SEC	_____	_____	_____	_____	27 <input type="checkbox"/> EXHAUST FLOW kg/SEC (1)	_____	_____	_____	_____	28 <input type="checkbox"/> FIRING TEMPERATURE °C	_____	_____	_____	_____	29 <input type="checkbox"/> GAS GEN. EXHAUST TEMP °C	_____	_____	_____	_____	30 <input type="checkbox"/> PT EXHAUST TEMP. °C	_____	_____	_____	_____	31 <input checked="" type="radio"/> CERTIFIED POINT (3.26)	YES	_____	_____	_____	32 (1) INCLUDING <input type="radio"/> STEAM <input type="radio"/> WATER EFFECTS FOR	_____	_____	_____	_____	33 <input checked="" type="checkbox"/> EMISSION CONTROL <input checked="" type="checkbox"/> AUGMENTATION (4.1.9)	_____	_____	_____	_____	34 <input type="checkbox"/> STEAM FLOW, kg/HR	_____	_____	_____	_____	35 <input type="checkbox"/> WATER FLOW, m³/HR	_____	_____	_____	_____	<input type="radio"/> INDOOR <input checked="" type="radio"/> OUTDOOR <input type="radio"/> GRADE <input type="radio"/> HEATED <input checked="" type="radio"/> UNDER ROOF <input type="radio"/> MEZZANINE <input checked="" type="radio"/> UNHEATED <input type="radio"/> PARTIAL SIDES <input checked="" type="radio"/> ONSHORE ELEC. AREA CLASSIFICATION (4.1.14) <input type="radio"/> NON-HAZARDOUS <input checked="" type="radio"/> HAZARDOUS APPLICABLE CODE: <input type="radio"/> NEC500 <input type="radio"/> NEC505 <input checked="" type="radio"/> IEC GROUP <u>IIA</u> CLASS: _____ TEMPERATURE CODE: <u>T3</u> AREA CLASSIFICATION <input type="radio"/> DIVISION <input checked="" type="radio"/> ZONE <u>2</u> <input type="radio"/> THIRD PARTY CERTIFICATION REQUIRED <input type="radio"/> WINTERIZATION REQD <input type="radio"/> <input checked="" type="radio"/> TROPICALIZATION REQD (5.4.6.6) UNUSUAL CONDITIONS: <input checked="" type="radio"/> DUST <input type="radio"/> FUMES <input checked="" type="radio"/> CORROSIVE AGENTS (4.10.1.1) _____ <input checked="" type="radio"/> SO2 ANNUAL MEAN - 6.01mg/m3, 24hr max - 10.66mg/m3 <input checked="" type="radio"/> OTHER (5.5.3.4) ONSHORE OIL&GAS NOISE SPECIFICATIONS: (4.1.10) <input checked="" type="radio"/> APPLICABLE TO MACHINE: (5.7.4.1) SEE SPECIFICATION <u>88</u> dBA at 1 meter <input type="radio"/> APPLICABLE TO NEIGHBORHOOD: (5.7.4.2) SEE SPECIFICATION _____
	SITE RATED (3.45)	NORMAL DUTY (3.26)	SITE MAX TEMP	SITE MIN TEMP																																																																																			
19 <input checked="" type="radio"/> DRY BULB TEMP, °C	45	_____	45	0																																																																																			
20 <input checked="" type="radio"/> RELATIVE HUMIDITY %	84	_____	84	37																																																																																			
21 <input checked="" type="radio"/> ALTITUDE (m)	197.8	_____	197.8	197.8																																																																																			
22 <input type="checkbox"/> OUTPUT, (KW) (1)	_____	_____	_____	_____																																																																																			
23 <input type="checkbox"/> HEAT RATE, LHV, MJ/ KW-HR	_____	_____	_____	_____																																																																																			
24 <input checked="" type="checkbox"/> OUTPUT SHAFT SPEED, RPM	_____	_____	_____	_____																																																																																			
26 <input type="checkbox"/> AIR FLOW kg/SEC	_____	_____	_____	_____																																																																																			
27 <input type="checkbox"/> EXHAUST FLOW kg/SEC (1)	_____	_____	_____	_____																																																																																			
28 <input type="checkbox"/> FIRING TEMPERATURE °C	_____	_____	_____	_____																																																																																			
29 <input type="checkbox"/> GAS GEN. EXHAUST TEMP °C	_____	_____	_____	_____																																																																																			
30 <input type="checkbox"/> PT EXHAUST TEMP. °C	_____	_____	_____	_____																																																																																			
31 <input checked="" type="radio"/> CERTIFIED POINT (3.26)	YES	_____	_____	_____																																																																																			
32 (1) INCLUDING <input type="radio"/> STEAM <input type="radio"/> WATER EFFECTS FOR	_____	_____	_____	_____																																																																																			
33 <input checked="" type="checkbox"/> EMISSION CONTROL <input checked="" type="checkbox"/> AUGMENTATION (4.1.9)	_____	_____	_____	_____																																																																																			
34 <input type="checkbox"/> STEAM FLOW, kg/HR	_____	_____	_____	_____																																																																																			
35 <input type="checkbox"/> WATER FLOW, m³/HR	_____	_____	_____	_____																																																																																			
37 APPLICABLE SPECIFICATIONS: 38 <input checked="" type="radio"/> API 616 GAS TURBINES FOR THE PETROLEUM, CHEMICAL, & GAS INDUSTRY SERVICES 39 <input type="radio"/> GOVERNING SPECIFICATION (IF DIFFERENT) _____ 40 _____ 41 _____ 42 <input checked="" type="radio"/> VENDOR HAVING UNIT RESPONSIBILITY (4.1.2) _____ 43 <u>Rolls-Royce</u>		PAINTING: <input checked="" type="radio"/> MANUFACTURER'S OFFSHORE STD. <input type="radio"/> OTHER _____ NOTE: All Data Sheets References to GG=Gas Generator SS = Single Shaft and PT = Power Turbine REMARKS: <u>Also see Rolls-Royce Deviations to API 616</u> _____ _____ _____ _____ _____																																																																																					
44 SHIPMENT: (6.4) 45 <input type="radio"/> DOMESTIC <input checked="" type="radio"/> EXPORT <input type="radio"/> EXPORT BOXING REQD. 46 <input type="radio"/> OUTDOOR STORAGE MORE THAN 6 MONTHS (6.4.1) 47 SPARE ROTOR ASSEMBLY PACKAGED FOR (6.4.3.10) 48 <input type="radio"/> DOMESTIC <input type="radio"/> EXPORT SHIPMENT 49 COMMENTS: _____																																																																																							

	ENGINEERS INDIA LIMITED NEW DELHI		R
COMBUSTION GAS TURBINE (API 616-4TH) DATA SHEET SI UNITS		SPEC NO. <u>6988-000-KA-MR-501</u> (ITEM NO. _____) REVISION NO. <u>0</u> DATE <u>5-Apr-09</u> PAGE <u>2</u> OF <u>10</u> BY <u>Leong, HT</u>	E
FUEL SYSTEM (5.8)			
2 TYPE <input checked="" type="radio"/> GAS (5.8.2) <input type="radio"/> LIQUID (5.8.3) <input type="radio"/> DUAL (5.8.1.5.1) 3 DUAL SYSTEM REQMTS (5.8.1.5.1) <input type="radio"/> GAS/GAS <input type="radio"/> GAS/LIQUID <input type="radio"/> LIQUID/LIQUID 4 <input type="radio"/> COMPLETE FUEL RECEIVING SYSTEM (5.8.1.1) <input type="radio"/> MAX. TIME ALLOWED TO COMPLETE TRANSFER _____ SECONDS			
GAS FUELS (5.8.2)		LIQUID FUELS (5.8.3)	
		FUEL GRADE (5.8.3.3)	
9 <input checked="" type="radio"/> FUEL ANALYSIS - MOL % (3.7.2.1) (3.7.1.8) 10 COMPOSITION: M.W. NORMAL STARTING ALT 11 AIR 29 THE FUEL GAS COMPOSITION 12 OXYGEN 32 IS AS INDICATED IN THE COMPRESSOR 13 NITROGEN 38 PROCESS DATA SHEET 14 WATER VAPOR 18 INCLUDED IN THIS SECTION. 15 HYDROGEN SULPHIDE 34 _____ 16 CARBON DIOXIDE 44 _____ 17 HYDROGEN 2 _____ 18 METHANE 16 _____ 19 ETHYLENE 26 _____ 20 ETHANE 30 _____ 21 PROPYLENE 42 _____ 22 PROPANE 44 _____ 23 I-BUTANE 58 _____ 24 N-BUTANE 58 _____ 25 I-PENTANE 72 _____ 26 N-PENTANE 72 _____ 27 HEXANE 86 _____ 28 HEPTANE 100 _____ 29 TOTAL _____ 30 AVG. MOL. WT. _____ 31 CORS AGENTS (5.8.2.3) PPM _____ 32 CONTMNTS)5.8.2.2.1) PPM _____ 33 LHV MJ/m ³ /HR (5.8.2.4) _____ 34 FUEL PRESS.MAX/MIN,kPag _____ 35 FUEL TEMP MAX/MIN °C / / / 36 <input type="checkbox"/> FUEL PRESS/TEMP REQD. 37 MIN BarA/DegC _____ 38 COMPRESSION SYS REQD (5.8.1.2.2) <input type="radio"/> YES <input type="radio"/> NO 39 HEATER REQD (5.8.2.1) <input type="checkbox"/> YES <input type="checkbox"/> NO 40 <input type="radio"/> RATE OF CHANGE OF LHV (5.8.2.4) _____ 41		ASTM D1655 ASTM <input type="radio"/> 0GT <input type="radio"/> 1GT JET <input type="radio"/> A <input type="radio"/> A-1 <input type="radio"/> B D2880 <input type="radio"/> 2GT <input type="radio"/> 3GT <input type="radio"/> 4GT <input type="radio"/> OTHER, INDICATE ANALYSIS BELOW (5.8.3.3 c) LIQUID FUEL TREATMENT REQUIRED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO TREATMENT SYSTEM BY (3.7.1.5) <input type="radio"/> VENDOR <input type="radio"/> OTHER FUEL TRANSFER EQUP REQUIRED (5.8.1.4.5) <input type="checkbox"/> YES <input type="checkbox"/> NO HEATER REQUIRED (5.8.1.4.4) <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> LIQ FUEL PRESS REQD, MAX/MIN,(kPaG) _____ / _____ FUEL ANALYSIS DATA (5.8.3.3) ASTM MEASURED <u>PROPERTY</u> <u>METHOD</u> <u>VALUE</u> VISCOSITY SSU, 38°C D-445 _____ DISTILLATION DATA D-86 _____ 50% RECOVERY °C MAX _____ END POINT °C MAX _____ SULFUR CONTENT %WT. MAX. (SELECT APPL. METHOD) BOMB METHOD D-129 _____ LAMP METHOD D-1266 _____ HIGH-TEMP METHOD D-1552 _____ CARBON RESIDUE (ON 10% BOTTOMS) % WT. MAX. _____ CONRADSON D-189 _____ RAMSBOTTOM D-524 _____ COPPER STRIP CORROSION PLATE D-130 _____ 3 HRS AT 100°C MAX AROMATIC CONTENT D-1319 _____ ASH CONTENT D-482 _____ SPECIFIC GRAVITY, 15°C D-1298 _____ FLASH POINT °C D-56 _____ POUR POINT °C D-97 _____ WATER D-95 _____ FILTERABLE DIRT. MG/100ML D-2276 _____ TRACE METALS (ATOMIC ABSORPTION PREFERRED) D-3605 _____ SODIUM _____ POTASSIUM _____ VANADIUM _____ CALCIUM _____ LEAD _____ OTHER METALS _____ LOWER HEATING VALUE MJ/kg D-2382 _____	
42 REMARKS: _____ 43 _____ 44 _____ 45 _____ 46 _____			
FUEL SYSTEM PIPING			
49 <input type="radio"/> BY PASS AND VENT VALVE (3.7.1.3) <input checked="" type="checkbox"/> ISOLATION BLOCK VALVES <input checked="" type="checkbox"/> ANSI FLANGE RATING 50 <input type="radio"/> TWIN Y-TYPE STRAINER WITH CONTINUOUS FLOW <input checked="" type="checkbox"/> NACE 2002 MATERIAL STANDARDS (4.10.1.8) 51 <input type="radio"/> TRANSFER VALVE (5.8.1.2.4) 52			



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501 (ITEM NO.)

REVISION NO. 0 DATE 5-Apr-09

PAGE 3 OF 10 BY Leong, HT

R
E
V

CONSTRUCTION FEATURES (NOTE 1)

SPEEDS: (POWER TURBINE)

MAX. CONT. 5090 RPM TRIP 5335 RPM

LATERAL CRITICAL SPEEDS (DAMPED)

FIRST CRITICAL _____ RPM _____ MODE

SECOND CRITICAL _____ RPM _____ MODE

THIRD CRITICAL _____ RPM _____ MODE

FOURTH CRITICAL _____ RPM _____ MODE

PROTOTYPE OR MODIFIED ROTOR SUPPORT (4.7.3.5)

LATERAL ANALYSIS REQUIRED (INDIVIDUAL COMPONENTS) (D.1.3)

TRAIN TORSIONAL ANALYSIS REQUIRED (2.7.4.5)

TORSIONAL CRITICAL SPEEDS:

FIRST CRITICAL Per API 616 _____ RPM

SECOND CRITICAL Per API 616 _____ RPM

THIRD CRITICAL _____ RPM

FOURTH CRITICAL _____ RPM

VIBRATION: (4.7.4.5) (7.2.3 o):

ALLOWABLE TEST LEVEL : SHAFT PT: 50 MICRONS P/P

CASE GG: 16 mm/sec

MATERIALS OF CONSTRUCTION (4.10)

COMPRESSOR ROTOR BLADES Titanium Alloy, FV.535, Inco 738 & 718, Nimonic 105

COMPRESSOR STATOR VANES Jethete 152 & EAX, Inco 718, Nimonic 105

SHAFT Steel BLADE/VANE COATING Sermetal 5375 & Waspalloy

TURBINE STAGE	NOZZLES	BLADES	WHEELS OR DISCS
1 (GG)	Mar-M-002	CMSX-4	Waspalloy
2 (GG)	C.1023	CMSX-4	Incoloy 901
3			
1 (PT)	Rene'80	Rene'80	901
2 (PT)	U-500	U-500	901
3 (PT)	N-155	U-500	901

COMBUSTORS C.263 and Nimonic 75

COMPRESSOR CASING Aluminum Alloy, Jethete EAX, Inco 907/904

COMBUSTOR CASING Jethete 152

TURBINE CASING GG: Nimonic P.E. 16, PT: Waspalloy, Inconel 718

ROTATION, VIEWED FROM DRIVE END CW CCW

GAUGE BOARDS AND CONTROL PANELS

AIR COMPRESSOR:

STAGES 7IP, 6HP MAX. TIP SPEED 5.85 m/SEC

TYPE Axial PRESSURE RATIO 21:1

CASING SPLIT (2.2.3) AXIAL RADIAL

ROTOR SOLID BUILT UP

GAUGE BOARDS

LOCATION _____

CONTROL PANELS (5.4.5.1.1) ON-SKID OFF SKID LOCAL

OFF SKID REMOTE

WEATHER PROTECTION REQUIRED YES NO

SPECIFICATION _____

ANNUNCIATOR REQUIRED (5.4.4.8.5)

VISUAL DISPLAY UNIT (VDU) KEYBOARD

TURBINE:

STAGES 1HP, 1LP, 3PT MAX. TIP SPEED 8.65(GG), 7.3(PT) m/SEC

CASING SPLIT (4.2.3) AXIAL (GG) RADIAL (PT)

ROTOR SOLID BUILT UP

COMBUSTORS: (4.3.2)

SINGLE MULTIPLE, NUMBER 9

GAS LIQUID DUAL FUEL

MAX. ALLOW TEMP. VARIATION +/-150 °C

APPLICABLE PLANE _____

FUEL NOZZLES PER COMBUSTOR 3

WOBBE INDEX NO REQD (4.3.7) MAX _____ MIN _____

CONTROL SYSTEMS

TYPE (5.4.1.5)

MECH PNEU HYDRA ELECTRIC ELECTRONIC

MICROPROCESSOR BASED COMBINED

SIGNAL SOURCE 4-20 mA, 24 V dc

SENSITIVITY _____ RANGE _____ TO _____

TIME OF AC OUTAGE RIDEOUT _____ MIN (5.4.1.6)

SHUT OFF VALVES FOR SHUT DOWN SENSORS (5.4.4.9)

STARTING SYSTEM (5.4.2.1)

MANUAL SEMI AUTOMATIC AUTOMATIC

PURGE (5.4.2.2) _____ MINUTES

SEPARATE SHUTDOWN VALVE TEST DURING OPERATION

MAINTENANCE INTERVALS, HOURS

HOT GAS PATH INSPECTIONS See Note 2

MAJOR OVERHAULS See Note 3

OTHER See Note 4

GOVERNOR (5.4.3)

MFR'S STD. OTHER MAKE _____ MODEL _____

CONSTANT SPEED VARIABLE SPEED

ISOCHRONOUS DROOP

REMOTE SHUTDOWN SIGNAL ELECTRIC

PNEUMATIC HYDRAULIC NONE

MANUAL SPEED CHANGER RPM 5090 MAX. 4610 MIN.

MAINTAIN TURBINE SPEED UPON FAILURE OF CONTROL SIGNAL OR ACTUATOR

NOTE (1) FOR MULTIPLE SHAFT TURBINES, COMPLETE ALL APPLICABLE PORTIONS FOR EACH SHAFT

REMARKS: (2) Half Life refurbishment required generally after 25,000 hours of operation; (3) Major overhaul of GG on condition (generally 50,000 hrs. operation); (4) Borescope Inspection recommended generally after 4,000 hrs operation



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501(ITEM NO. _____)

REVISION NO. 0 DATE 5-Apr-09

PAGE 4a OF 10 BY Leong, HT

R
E
V

1 CONSTRUCTION FEATURES CONTINUED (NOTE 1)					
2 RB211 GAS GENERATOR BEARINGS AND BEARING HOUSINGS (4.8)					
3 RADIAL (ROLLER, SQUEEZE-FILM TYPE)	HP & IP Turbine	IP Compressor	THRUST (LOCATION TYPE)	IP Compressor	HP Compressor
4 <input checked="" type="checkbox"/> TYPE	Anti-Friction	Anti-Friction	<input checked="" type="checkbox"/> TYPE	Anti-Friction	Anti-Friction
5 <input checked="" type="checkbox"/> MANUFACTURER	RHP/FAG (TYP)	RHP (TYP)	<input checked="" type="checkbox"/> MANUFACTURER	RHP/FAG (TYP)	RHP (TYP)
6 <input checked="" type="checkbox"/> BEARING WIDTH, mm	39.6	24.3	<input checked="" type="checkbox"/> BEARING WIDTH, mm	63.4	76.2
7 <input checked="" type="checkbox"/> OUTER/INNER DIAMETER, mm	254.4 / 221.6	285.5 / 252.1	<input checked="" type="checkbox"/> OUTER/INNER DIAMETER, mm	215.9 / 139.7	215.8 / 127.0
8 <input type="checkbox"/> UNIT LOAD (ACT/ALLOW) kPa			<input type="checkbox"/> UNIT LOAD (MAX POTEN.), kPa		
9 <input checked="" type="checkbox"/> OUTER RACE MATERIAL	AMS6491	AMS6491	<input checked="" type="checkbox"/> OUTER RACE MATERIAL	MSRR6113	MSRR6083
10 <input checked="" type="checkbox"/> ROLLER MATERIAL	AMS6491	AMS6491	<input checked="" type="checkbox"/> ROLLER MATERIAL	MSRR6113	MSRR6083
11 <input checked="" type="checkbox"/> CAGE MATERIAL	AMS6415	AMS6415	<input checked="" type="checkbox"/> CAGE MATERIAL	MSRR6083	MSRR6013
12 <input type="checkbox"/> LOAD: BETWEEN/ON PAD			<input checked="" type="checkbox"/> L10 LIFE (On Condition), h	>50,000	>50,000
13 <input type="checkbox"/> PIVOT: CENTER/OFFSET, %			LUBRICATION: <input type="checkbox"/> FLOODED <input checked="" type="checkbox"/> SCAVENGE SYSTEM		
14 <input type="checkbox"/> DAMPER BEARING			THRUST COLLAR: <input type="checkbox"/> INTEGRAL <input checked="" type="checkbox"/> REPLACEABLE		
15 <input checked="" type="checkbox"/> L10 LIFE (On Condition), h	>50,000	>50,000	BEARING MATERIAL		
16 BEARING TEMPERATURE DEVICES (4.8.5.5)	<input type="checkbox"/> SEE ATTACHED API-670 DATA SHEET		VIBRATION DETECTORS: (4.8.5.3)	<input type="checkbox"/> SEE ATTACHED API-670 DATA SHEET	
17 <input type="checkbox"/> THERMOCOUPLES			RADIAL VIBRATION DETECTORS		
18 <input type="checkbox"/> SELECTOR SWITCH & IND. BY: PURCH MFR			<input type="checkbox"/> TYPE	<input checked="" type="checkbox"/> MODEL	
19 <input type="checkbox"/> RESISTANCE TEMP DETECTORS			<input checked="" type="checkbox"/> MFR		
20 <input type="checkbox"/> RESISTANCE MATL <input type="checkbox"/> OHMS			<input type="checkbox"/> NO. AT EACH SHAFT BEARING	TOTAL NO.	
21 <input type="checkbox"/> SELECTOR SWITCH & IND. BY: PURCH MFR			<input type="checkbox"/> OSCILLATOR-DEMODULATOR SUPPLIED BY		
22 <input type="checkbox"/> LOCATION-JOURNAL BEARING			<input type="checkbox"/> MFR	<input type="checkbox"/> MODEL	
23 NUMBER EA PD EVERY OTH PAD PER BRG			<input type="checkbox"/> MONITOR SUPPLIED BY (5.4.7.8.2)		
24 OTHER			<input type="checkbox"/> LOCATION	ENCLOSURE	
25 <input type="checkbox"/> LOCATION-THRUST BEARING			<input type="checkbox"/> MFR	<input type="checkbox"/> MODEL	
26 NO. (ACT) EA PD EVERY OTH PAD PER BRG			<input type="checkbox"/> SCALE RGE	<input type="checkbox"/> ALARM SET @ uM	
27 OTHER			<input type="checkbox"/> SHTDOWN <input type="checkbox"/> SET @ uM	<input type="checkbox"/> TIME DELAY SEC	
28 NO. (INACT) EA PD EVERY OTH PAD PER BRG			AXIAL POSITION DETECTOR (4.8.5.3):	NOT REQUIRED	
29 OTHER			<input type="checkbox"/> SEE ATTACHED API-670 DATA SHEETS		
30 <input type="checkbox"/> MONITOR SUPPLIED BY (5.4.7.5)			<input type="checkbox"/> TYPE	<input checked="" type="checkbox"/> MODEL	
31 <input type="checkbox"/> LOCATION	ENCLOSURE		<input checked="" type="checkbox"/> MFR	<input type="checkbox"/> NO. REQUIRED	
32 <input type="checkbox"/> MFR	<input type="checkbox"/> MODEL		<input type="checkbox"/> OSCILLATOR-DEMODULATOR SUPPLIED BY		
33 <input type="checkbox"/> SCALE RGE	<input type="checkbox"/> ALARM SET @ °C		<input type="checkbox"/> MFR	<input type="checkbox"/> MODEL	
34 <input type="checkbox"/> SHTDOWN <input type="checkbox"/> SET @ °C	<input type="checkbox"/> TIME DLY SEC		<input type="checkbox"/> MONITOR SUPPLIED BY (3.4.7.8.2)		
35 REMARKS:			<input type="checkbox"/> LOCATION	ENCLOSURE	
36			<input type="checkbox"/> MFR	<input type="checkbox"/> MODEL	
37			<input type="checkbox"/> SCALE RGE	<input type="checkbox"/> ALARM SET @ uM	
38			<input type="checkbox"/> SHTDOWN <input type="checkbox"/> SET @ uM	<input type="checkbox"/> TIME DELAY SEC	
39			ACCELERATION TRANSDUCERS		
40			<input type="checkbox"/> SEE ATTACHED API-670 DATA SHEETS		
41			<input checked="" type="checkbox"/> MFR Vibrometer Inc.	<input checked="" type="checkbox"/> MODEL CE135	
42			<input checked="" type="checkbox"/> LOCATION GG Casing	<input checked="" type="checkbox"/> NUMBER 3	
43			<input checked="" type="checkbox"/> MONITOR SUPPLIED BY (3.4.7.8.4)	Rolls-Royce	
44			<input checked="" type="checkbox"/> LOCATION UCP	ENCLOSURE	
45			<input checked="" type="checkbox"/> MFR Bently-Nevada	<input checked="" type="checkbox"/> MODEL 3500	
46			<input type="checkbox"/> SCALE RGE	<input checked="" type="checkbox"/> ALARM SET @ < 25 mm/s	
47			<input checked="" type="checkbox"/> SHTDOWN <input checked="" type="checkbox"/> SET @ 40 mm/s	<input checked="" type="checkbox"/> TIME DELAY 0 SEC	
48 NOTES	(1) FOR MULTIPLE SHAFT TURBINES, COMPLETE ALL APPLICABLE PORTIONS FOR EACH SHAFT				
49	(2) FOR THREE BEARING SHAFTS, USE A SEPARATE SHEET FOR THE EXTRA BEARING				
50	(3) FOR ROLLING ELEMENT BEARINGS, MODIFY ENTRIES AS REQUIRED. SHOW L-10 BEARING LIFE				



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501 (ITEM NO. _____)

REVISION NO. 0 DATE 5-Apr-09

PAGE 4b OF 10 BY Leong, HT

R
E
V

CONSTRUCTION FEATURES CONTINUED (NOTE 1)

RT61 POWER TURBINE BEARINGS AND BEARING HOUSINGS (4.8)

RADIAL (NOTES 2 AND 3)		DISC	CPLG	THRUST (NOTE 3)		ACTIVE	INACTIVE
<input checked="" type="checkbox"/> TYPE	TILT PAD	TILT PAD	<input checked="" type="checkbox"/> TYPE	TILT PAD	Collar		
<input checked="" type="checkbox"/> MANUFACTURER	KMC	Waukesha	<input checked="" type="checkbox"/> MANUFACTURER	Waukesha (TYP)	Waukesha		
<input checked="" type="checkbox"/> LENGTH, mm	102	89	<input checked="" type="checkbox"/> UNIF LOAD (ULTIMATE), kg				
<input checked="" type="checkbox"/> SHAFT DIAMETER, mm	254	203	<input checked="" type="checkbox"/> UNIF LOAD (SITE RATED), kg	19,047	N/A		
<input checked="" type="checkbox"/> UNIF LOAD (ACT/ALLOW), kg	21129 / 65834	667 / 42569.0	<input checked="" type="checkbox"/> UNIF LOAD (MAX POTEN.), kg	50439	N/A		
<input checked="" type="checkbox"/> BASE MATERIAL	Steel	Steel	<input checked="" type="checkbox"/> NO. OF PADS / AREA (mm ²)	9 / 86451	0 / N/A		
<input checked="" type="checkbox"/> BABBITT THICKNESS, mm	5.08	1.3	<input checked="" type="checkbox"/> BASE MATERIAL	Steel	Steel		
<input checked="" type="checkbox"/> NO. PADS	4	4	<input type="checkbox"/> BABBITT THICKNESS, mm				
<input checked="" type="checkbox"/> LOAD: BETWEEN/ON PAD	Between	Between	<input type="checkbox"/> PIVOT: CENTER/OFFSET, %				
<input checked="" type="checkbox"/> PIVOT: CENTER/OFFSET, %	60	60	LUBRICATION: <input checked="" type="checkbox"/> FLOODED <input type="checkbox"/> DIRECTED				
<input checked="" type="checkbox"/> DAMPER BEARING	YES	NO	THRUST COLLAR: <input type="checkbox"/> INTEGRAL <input checked="" type="checkbox"/> REPLACEABLE				

BEARING TEMPERATURE DEVICES (4.8.5.5) SEE ATTACHED API-670 DATA SHEET

THERMOCOUPLES
 SELECTOR SWITCH & IND. BY: _____ PURCH _____ MFR

RESISTANCE TEMP DETECTORS
 RESISTANCE MAT'L Platinum 100 OHMS

SELECTOR SWITCH & IND. BY: _____ PURCH MFR

LOCATION-JOURNAL BEARING
NUMBER 1 EA PD EVERY OTH PAD 2 PER BRG

OTHER _____

LOCATION-THRUST BEARING
NO. (ACT) 1 EA PD EVERY OTH PAD 2 PER BRG

OTHER _____

NO. (INACT) EA PD EVERY OTH PAD 2 PER BRG

OTHER NONE REQUIRED

MONITOR SUPPLIED BY (5.4.7.5) Rolls-Royce

LOCATION TCP ENCLOSURE _____

MFR RR Controls MODEL _____

SCALE RGE _____ ALARM SET @ 120 °C

SHTDOWN SET @ 130 °C TIME DLY _____ SEC

REMARKS: _____

NOTES (1) FOR MULTIPLE SHAFT TURBINES, COMPLETE ALL APPLICABLE PORTIONS FOR EACH SHAFT

(2) FOR THREE BEARING SHAFTS, USE A SEPARATE SHEET FOR THE EXTRA BEARING

(3) FOR ROLLING ELEMENT BEARINGS, MODIFY ENTRIES AS REQUIRED. SHOW L-10 BEARING LIFE



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501(ITEM NO. _____)

REVISION NO. 0 DATE 5-Apr-09

PAGE 5 OF 10 BY Leong, HT

R
E
V

UTILITIES: CONNECTIONS

UTILITY CONDITIONS: N/A N/A

STEAM: **AUXILIARY DRIVERS** **HEATING**

INLET MIN _____ kPag _____ °C _____ kPag _____ °C

NORM _____ kPag _____ °C _____ kPag _____ °C

MAX _____ kPag _____ °C _____ kPag _____ °C

EXHST MIN. _____ kPag _____ °C _____ kPag _____ °C

NORM _____ kPag _____ °C _____ kPag _____ °C

MAX _____ kPag _____ °C _____ kPag _____ °C

STARTING **N/A** **INJECTION** **N/A**

INLET MIN _____ kPag _____ °C _____ kPag _____ °C

NORM _____ kPag _____ °C _____ kPag _____ °C

MAX _____ kPag _____ °C _____ kPag _____ °C

EXHST MIN. _____ kPag _____ °C

NORM _____ kPag _____ °C

MAX _____ kPag _____ °C

TOTAL UTILITY CONSUMPTION:

COOLING WATER _____ m³/HR

STEAM LEVEL N/A kPag _____ kPag _____ kPag

STEAM, NORMAL N/A _____ kg/HR

STEAM, MAX N/A _____ kg/HR

INSTRUMENT AIR See Utility List in Proposal Nm³/HR

MOTORS (AUXILIARIES) See Utility List in Proposal kW

BATTERY CHARGERS See Utility List in Proposal kW

HEATERS See Utility List in Proposal kW

PURGE (AIR OR N₂) See Utility List in Proposal Nm³/HR

TURBINE AIR EXTRACTION REQUIRED: (4.1.22)

Nm³/HR _____ @ _____ kPag

MAXIMUM PRESSURE AVAILABLE _____ kPag

MINIMUM SPEED _____ RPM

DISCHARGE TEMPERATURE _____ °C

COMPRESSOR EXTRACTION STAGE NUMBER _____

ELECTRICITY: (5.4.6.1) PILOT LIGHT INDICATORS

	MOTORS	HEATING	CONTROL	SHUTDOWN
VOLTAGE	400	230	230	230
HERTZ	50	50	50	50
PHASE	3	1	1	1

COOLING WATER:

INLET TEMP. _____ °C MAX RETURN _____ °C

DESIGN TEMPERATURE _____ °C

NORM PRESS _____ kPag MIN RETURN _____ kPag

DESIGN PRESS _____ kPag MAX ALLOW D P _____ kPaD

WATER SOURCE _____

INSTRUMENT AIR PRESSURE DESIGN, kPag

MAX 1000 NORMAL 790 MIN 650

REMARKS:

FOR FULL DETAILS OF UTILITY REQUIREMENTS OF THIS GAS TURBINE PACKAGE PLEASE REFER TO THE UTILITY SCHEDULE ATTACHED UNDER TECHNICAL PROPOSAL.

REMARKS:

PURCHASER CONNECTIONS

CONNECTION	DESIGN APPROVAL REQ'D (4.10.4.6.4)	SIZE	FACING and RATING	POSITION (4.4.1)	FLANGED OR STUDD (4.4.1)	MATING FLG & GASKET BY VENDOR (4.4.5.4)	GAS VELOCITY m/SEC
INLET	No			TOP / SIDE			
EXHAUST	No			TOP			
GAS FUEL SUPPLY	No	2"	600# RF		Flanged	Yes	
STEAM	N/A			N/A			
WATER	N/A			N/A			
GAS FUEL VENT	No	1"	150# RF		Flanged		
AUXILIARY AIR SUPPLY	No	0.75"	FNPT				



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501 (ITEM NO. _____)

REVISION NO. 0 DATE 5-Apr-09

PAGE 6 OF 10 BY Leong, HT

R
E
V

INSTRUMENTS									
DESCRIPTION	INSTRUMENT TYPE		INSTRUMENT LOCATION			TRANS-MITTERS FURNISHED BY		CONTROL ROOM RECEIVERS FURN BY	
	INDICATING	RECORDING	LOCAL	LOCAL PANEL	CONTROL ROOM	VENDOR	OTHERS	VENDOR	OTHERS
GAS GENERATOR OR SINGLE SHAFT GAS TURBINE									
TACHOMETER(S) (NO. <u>2</u>)	●	●	○	○	●	●	○	●	○
Δ P AIR INLET SYSTEM	●	○	●	○	●	●	○	●	○
COMPRESSOR DISCHARGE PRESSURE	●	○	○	●	●	●	○	●	○
FUEL FILTER Δ P	○	○	○	○	○	○	○	○	○
FUEL SUPPLY PRESSURE	●	○	○	○	●	●	○	●	○
STARTING GAS SUPPLY PRESSURE	●	○	○	●	○	○	○	○	○
STARTING GAS EXHAUST PRESSURE	○	○	○	○	○	○	○	○	○
TEMP COMBUSTOR MEASUREMENT (6 PTS MIN) 4.3.2)	●	●	○	○	●	●	○	●	○
TEMP GAS TURB CONTROL PLANE (6 PTS MIN)	○	○	○	○	○	○	○	○	○
INLET AIR TEMPERATURE	●	●	●	○	●	●	○	●	○
TEMPERATURE GG COMPRESSOR DISCHARGE	●	●	○	○	●	●	○	●	○
TEMPERATURE THRUST BEARING OIL DRAIN	○	○	○	○	○	○	○	○	○
TEMPERATURE EACH BEARING SUMP (ROLLING ELEMENT TYPE)	○	○	○	○	○	○	○	○	○
TEMPERATURE FUEL MANIFOLD GAS SUPPLY	●	○	○	○	●	●	○	●	○
TEMPERATURE LUBE OIL RESERVOIR	●	○	○	○	●	●	○	●	○
FIRED HOUR METER	●	●	○	○	●	●	○	●	○
A) NUMBER STARTS COUNTER	●	○	○	○	●	●	○	●	○
B) START SEQUENCE TIMER	●	○	○	○	●	●	○	●	○
LUBE OIL RESERVOIR LEVEL	●	○	●	○	●	●	○	●	○
LUBE OIL PUMP PRESSURE INDICATORS (NO <u>2</u>)	●	○	○	●	○	○	○	○	○
LUBE OIL COOLER OIL INLET TEMPERATURE	○	○	○	○	○	○	○	○	○
LUBE OIL COOLER OIL OUTLET TEMPERATURE	●	○	○	○	●	●	○	●	○
LUBE OIL COOLER COOLANT INLET TEMPERATURE	○	○	○	○	○	○	○	○	○
LUBE OIL COOLER COOLANT OUTLET TEMPERATURE	○	○	○	○	○	○	○	○	○
LUBE OIL FILTER Δ P	●	○	○	●	○	●	○	●	○
LUBE OIL PRESSURE EACH LEVEL (NO. <u>1</u>)	●	○	○	●	●	●	○	●	○
CONTROL OIL PRESSURE	●	○	○	●	●	●	○	●	○
SITE FLOW INDICATOR EACH DRAIN (NO. <u>N/A</u>)	○	○	○	○	○	○	○	○	○
INLET GUIDE VANE POSITION INDICATOR	●	○	○	○	●	●	○	●	○
EXHAUST DUCT Δ P INDICATOR	○	○	○	○	○	○	○	○	○
ENCLOSURE COOLING AIR EXHAUST TEMPERATURE	●	○	○	○	●	●	○	●	○
POWER TURBINE									
TACHOMETER(S) (NO. <u>1</u>)	●	○	○	○	●	●	○	●	○
EXHAUST TEMPERATURE (2 PTS MIN)	○	○	○	○	○	○	○	○	○
JOURNAL BEARING TEMPERATURE	●	○	○	○	●	●	○	●	○
THRUST BEARING TEMPERATURE	●	○	○	○	●	●	○	●	○
BEARING DRAIN TEMPERATURE	○	○	○	○	○	○	○	○	○
SITE FLOW INDICATOR EACH DRAIN (NO. <u>1 COMMON</u>)	●	○	●	○	○	○	○	○	○
LUBE OIL INLET PRESSURE	●	○	○	●	●	○	○	●	○
LUBE OIL INLET TEMPERATURE	○	○	○	○	○	○	○	○	○



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501(ITEM NO.

REVISION NO. 0 DATE 5-Apr-09

PAGE 7 OF 10 BY Leong, HT

R
E
V

ALARMS AND SHUTDOWNS (5.4.4)							
DESCRIPTION	APPLIES TO:		(5.4.4.8.5) ANNUNCIATOR POINT IN VENDOR FURNISHED CONTROL PANEL		SENSING DEVICES TO BE FURNISHED BY		INDICATING LIGHT ONLY
	SINGLE SHAFT OR G.G.	SEP PWR TURB.	(1)		VENDOR	OTHERS	
			ALARM	SHUT- DOWN			
							(2)
9 RADIAL SHAFT VIBRATION (NO. 4)	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
10 AXIAL THRUST POSITION (NO. 2)	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
11 OVERSPEED (1) (NO. 3)	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
12 CASING VIBRATION (NO. 3)	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
13 HIGH THRUST BEARING TEMP	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
14 HIGH RADIAL BEARING TEMP	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
15 LOW FUEL SUPPLY PRESSURE	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
16 HIGH FUEL FILTER Δ P	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
17 GAS TURBINE TEMPERATURE SPREAD HIGH	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
18 EXHAUST OVER TEMP	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
19 FAILURE OF OVER-TEMP SHUTDOWN DEVICE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
20 HIGH INLET AIR Δ P EACH FILTER	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
21 COMBUSTOR FLAME-OUT (GG UNDERSPEED)	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
22 CHIP DETECTOR, ANTI FRICTION BEARING	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
23 FAILURE STARTING CLUTCH TO ENGAGE OR DISENGAGE	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
24 LOW OIL PRESSURE (NO. 2)	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
25 HIGH LUBE OIL TEMP	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
26 LOW LUBE OIL RESERVOIR LEVEL	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
27 HIGH LUBE OIL RESERVOIR LEVEL	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
28 HIGH OIL FILTER Δ P (NO. 2)	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
29 LUBE OIL SPARE PUMP OPERATING	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="checkbox"/>
30 LOW CONTROL OIL PRESSURE	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
31 LOW STARTING GAS PRESSURE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
32 ANTI-ICING SYSTEM - NOT OPERATING			<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
33 LOW D.C. VOLTAGE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
34 EMERGENCY D.C. PUMP OPERATING	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
35 RESERVOIR HEATER "ON"			<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
36 IMPLOSION DOOR OPEN			<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
37 EXTERNAL PERMISSIVE START SIGNAL	<input checked="" type="radio"/>		<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="checkbox"/>
38 EXTERNAL SHUTDOWN SIGNAL	<input checked="" type="radio"/>		<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="checkbox"/>
39 LOSS OF AUX COOLING AIR	<input type="radio"/>		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
40 LAMP TEST PUSH BUTTON	<input type="radio"/>		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
41 ENCLOSURE HIGH TEMPERATURE	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
42 CONTROL SIGNAL FAILURE	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
43 CONTROL SYSTEM ACTUATOR FAILURE	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
44 GOVERNOR FAILURE	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
45 ENCLOSURE VENT FAN FAILURE	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
46	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="checkbox"/>
47							
48							

NOTES: (1) VENDOR TO ADVISE METHOD OF ANNUNCIATION
(2) VDU MAY USE MESSAGE INDICATOR



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501 (ITEM NO. _____)

REVISION NO. 0 DATE 5-Apr-09

PAGE 8 OF 10 BY Leong, HT

R
E
V

ACCESSORIES SUPPLIED BY GAS TURBINE MANUFACTURER

STARTING AND HELPER DRIVERS 5.1)

- STARTER ONLY (5.1.1.2) STARTER/HELPER (5.1.1.3)
- TYPE (5.1.1.1) MOTOR STEAM TURBINE
- GAS EXPANDER IC ENGINE HYDRAULIC
- GAS TURBINE STARTER IS CLUTCHED (5.1.1.7)
- HELPER RATING (5.1.2.2) _____ kW
- STARTER RATING (5.1.2.1) _____ kW
- SHAFT TURNING DEVICE REQUIRED (5.1.3.1)

MOTOR

TYPE _____ RATING 185 kW

MFR _____ MODEL _____

STEAM TURBINE (REFERENCE API DATA SHEETS)

MFR _____ MODEL _____

kW _____ MAX. STEAM FLOW _____ kg/HR

TOTAL/START _____ kg

GAS EXPANDER

APPLICABLE SPEC. (5.1.1.6)

MFR _____ MODEL _____

kW _____ MAX. GAS FLOW _____ kg/HR

TOTAL/START _____ kg

GAS FOR EXPANSION TURBINE:

	MIN	MAX	NORMAL
INLET PRESSURE, (kPa)	_____	_____	_____
EXHAUST PRESS, (kPa)	_____	_____	_____
GAS TEMP., °C INLET	_____	_____	_____
GAS TEMP., °C EXHAUST	_____	_____	_____
MOLECULAR WEIGHT	_____	_____	_____

SPEED CONTROL GOVERNOR PRESSURE REGULATOR

	YES	NO
INLET CONTROL VALVE FURNISHED	_____	_____
STAINLESS STEEL PIPING MANIFOLD	_____	_____
CARBON STEEL FLANGES	_____	_____
Y-STRAINER W/BREAKOUT FLANGES	_____	_____
LOW SPEED CAPABILITY (FOR COMPRESSOR CLEANING)	_____	_____
RELIEF VALVE PRESSURE SET POINT _____ kPag	_____	_____
CASING MATERIAL _____	_____	_____
SEAL TYPE _____	_____	_____

INTERNAL COMBUSTION ENGINE

TYPE SPARK IGNITED DIESEL

APPLICABLE SPECIFICATION (5.1.1.6)

MFR _____ MODEL _____

SPEED _____ RPM POWER _____ kW

COMBUSTION GAS TURBINE

APPLICABLE SPEC (5.1.1.6)

MFR _____ MODEL _____

SPEED _____ RPM POWER _____ kW

- GEARS: SEE SEPARATE API 613 GEAR DATA SHEETS (5.2.1.1)
- DRIVEN EQUIPMENT., SEE SEPARATE DATA SHEETS
- FIRE PROTECTION EQUIPMENT (5.7.3.1)
- TYPE HALON 1301 WATER MIST CO₂
- TYPE OF SENSOR NUMBER OF DETECTORS
- HEAT NUMBER 2
- INFRARED NUMBER 3
- INFRARED GAS DETECTORS NUMBER 8

MOUNTING PLATES (5.3)

TYPE (5.3.1.1) SOLEPLATE BASEPLATE

SHIM PACK THICKNESS _____ mm (5.3.1.2.9)

BASEPLATE (5.3.2)

- FURNISHED BY **Rolls-Royce** (5.3.2.1)
- GAS TURBINE ONLY EXTENDED FOR _____
- SUB-SOLEPLATES REQ'D (5.3.2.7) DRIP RIM
- COLUMN MOUNTING (5.3.2.4)(3-POINT) LEVELING PADS (3.3.2.2)

ENCLOSURES (5.7.5)

- ENCLOSURE REQUIRED
- REQUIREMENTS (5.7.5.1)
 - ACOUSTICAL
 - WEATHERPROOF
 - SAFETY
 - FIREPROTECTION
 - POSITIVE VENTILATION (2 X 100%)

COUPLINGS AND GUARDS (5.2.2)

- SEE ATTACHED API-671 DATA SHEETS
- MANUFACTURER _____ TYPE **Dry Flexible**
- MODEL _____ GUARD SUPPLIED BY _____
- MAXIMUM OUTSIDE DIAMETER _____ mm
- HUB WEIGHT _____ kg
- SPACER LENGTH _____ mm SPACER WEIGHT _____ kg
- IDLING ADAPTER REQ'D SOLO PLATE REQ'D
- GUARD SUPPLIED BY **Rolls-Royce**
- TYPE: FULLY ENCLOSED SEMI-OPEN OTHER _____
- LUBRICATING REQUIREMENTS:
 - NON-LUBE GREASE CONT. OIL LUBE
- QUANTITY PER HUB _____ kg or m³/HR

REMARKS: _____



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501 (ITEM NO. _____)

REVISION NO. 0 DATE 5-Apr-09

PAGE 9 OF 10 BY Leong, HT

R
E
V

ACCESSORIES SUPPLIED BY GAS TURBINE MANUFACTURER

INLET SYSTEM

EXHAUST SYSTEM

AIR FILTER (5.5.4.1) **UPDRAFT STATIC FILTER W/ PREFILTER WRAPS**

INERTIAL TYPE SEPARATOR MEDIA FILTERS

PREFILTER WRAP COMBINATION

SELF CLEANING (PULSE TYPE)

SINGLE STAGE WITH PROVISION FOR

FUTURE EXTRA STAGES YES NO

NORMAL DUST LOADING _____ kg/Nm³/HR

WIND DESIGN VELOCITY 44 m/sec

SNOW LOAD _____ kg/m²

SEISMIC ZONE **NON-SEISMIC**

LOCATION: GROUND LEVEL ELEVATED (5.5.4.6)

FILTRATION EFFICIENCY _____ % (5.5.4.3)

MAINTENANCE INTERVAL _____ MONTHS

CLEANING FREQUENCY _____ DAYS

IMPLOSION DOOR (5.5.4.5)

EVAPORATIVE COOLER (5.6.1.1) ANTI-ICING (5.5.3.10)

LIQUID TO AIR EXCHANGER (5.6.2.2)

WALKWAYS, LADDERS, HANDRAILS REQUIRED (5.6.1.5)

COMP CLEANING SYSTEM, TYPE Crank Soak Wash (5.5.3.9)

SILENCER PLATE ELEMENT MAT'L (5.5.5.1.4) 304 SST

FILTER MFR. _____ MODEL _____

@ 110% RATED AIR FLOW ΔP _____ mm H₂O

CLEAN _____ mm H₂O ALARM _____ mm H₂O

COOLER MFR. _____ MODEL _____ ΔP _____ mm H₂O

EXCHANGER MFR (5.6.2.3) _____

MODEL _____ ΔP _____ mm H₂O

DUCTING GAUGE / MATERIAL _____ / See remark-1

EXPANSION JOINT MFR _____ TYPE _____

SILENCER MFR _____ ΔP _____ mm H₂O

MANOMETER MFR _____ MODEL _____

RANGE _____ mm H₂O

SYSTEM SITE RATED PRESSURE DROP 100 mm H₂O

@ 110% RATED AIR FLOW

REMARKS 1. Combustion air intake inside skin -304SST, outside skid
is carbon steel

EXTENT OF FURN. INSULATION (SEE SKETCH) (5.7.1.2)

(RELIEF) (DIVERSION) VALVE (5.5.6.8)

EXHAUST HEAT RECOVERY SYSTEM (5.5.3.1)

EMISSION CONTROL SYSTEM (5.5.3.1)

EXHAUST SILENCER PLATE ELEMENT MATERIAL (5.5.5.2.3) _____

CARBON STEEL W/ 409 SST FLOW LINER

EMISSIONS SAMPLING SYSTEM (5.5.6.10)

EXPANSION JOINT MFR _____ TYPE _____

DUCTING GAUGE/MATERIAL _____ / _____

SILENCER MFR _____ ΔP _____ mm H₂O

HEAT RECOVERY DEVICE

MFR _____ TYPE _____ ΔP _____ mm H₂O

STEAM GEN: PRESS _____ kPag TEMP _____ °C

RATE _____ kg/HR

MANOMTR MFR _____ MODEL _____ RANGE _____ mm H₂O

ATMOSPHERIC RELIEF DEVICE (5.5.6.8)

TYPE _____ MFR _____ LOCATION _____

SYSTEM SITE RATED PRESSURE DROP 250 mm H₂O

ATMOSPHERIC EMISSIONS

EMISSION SUPPRESSION SYSTEM REQUIRED (5.8.4.1)

NO_x REQUIREMENTS (5.5.3.1.1) 100PPMV @15% O2

NO_x EMITTED _____

EMISSIONS REDUCTION METHOD (IF REQUIRED) (5.8.4.2)

WATER INJECTION (5.8.4.4) SCR

STEAM (5.8.4.4) DRY COMBUSTOR

OTHER _____

SO_x REQUIREMENTS _____

SULFUR CONTENT OF FUEL _____

SO_x EMITTED (BASED ON STATED SULFUR CONTENT) _____

CO REQUIREMENTS _____

CO EMITTED _____

PARTICULATE REQUIREMENTS _____

PARTICULATE EMITTED _____

UNBURNED HC REQUIREMENTS _____

UNBURNED HC EMITTED _____

APPLICABLE EMISSION CODES OR REGULATIONS

EPA - TITLE 40 - CFR OTHERS _____

SPECIALIZED INSTRUMENTS

TACHOMETERS (5.4.7.2.2)

TYPE ELECTRICAL ELECTRONIC

ANALOG DIGITAL

MANUFACTURER Rolls-Royce Controls

OIL FILLED PRESSURE GAUGES (5.4.7.6)

SWITCHES: (5.4.4.8.2)

CIRCUIT SHALL

ENERGIZE DEENERGIZE TO ALARM

ENERGIZE DEENERGIZE TO SHUTDOWN

ENCLOSURES

EXPLOSION PROOF WEATHER PROOF



ENGINEERS INDIA LIMITED
NEW DELHI

COMBUSTION GAS TURBINE (API 616-4TH)
DATA SHEET
SI UNITS

SPEC NO. 6988-000-KA-MR-501 (ITEM NO. _____)

REVISION NO. 0 DATE 5-Apr-09

PAGE 10 OF 10 BY Leong, HT

R
E
V

INSPECTION AND TESTING; LUBRICATION, WEIGHTS

SHOP INSPECTION AND TESTS: (6.1.1)

WIT- OBSER-
REQ NESSED VED

4	SHOP INSPECTION (6.1.2)	●		
5	CLEANLINESS (6.2.3.3)	●		
6	HYDROSTATIC (6.3.2)	●	○	○
7	MECHANICAL RUN (6.3.3)	●	●	○
8	<input type="checkbox"/> CONTRACT COUPLING			
9	<input type="checkbox"/> IDLING ADAPTOR(S)			
10	<input checked="" type="checkbox"/> CONTRACT PROBES			
11	<input type="checkbox"/> SHOP PROBES			
12	VIBRATION PLOTS (6.3.3.3.4)	●		
13	TAPE RECORD VIB DATA (6.3.3.6)	○		
14	PERFORMANCE TEST (6.3.4.1) (PTC-22)	●	●	○
15	NO LOAD STRING TEST (ONE PER STATION)	●	●	○
16	PACKAGE TEST (6.3.4.2.1)	○	○	○
17	LOAD GEAR TEST (6.3.4.3)	○	○	○
18	NOISE SURVEY (6.3.4.4) (DURING STRING TEST)	●	●	○
19	AUXILIARY EQUIPMENT (6.3.4.5)	●	○	○
20	POST TEST INSPECTION (6.3.4.6)	○	○	○
21	UCP FAT	●	○	○
22	GOVERNOR RESPONSE TEST (6.3.4.8)	○	○	○
23	SPARE PARTS (6.3.4.9)	○	○	○
24	FIRE PROTECTION SIMULATION (6.3.4.10)	○	○	○
25	OTHER (6.3.4.11) _____	○	○	○

LUBRICATION SYSTEMS (4.9)

● SEE API 614 DATA SHEETS **MINERAL OIL SYSTEM**
 LUBE OIL VISCOSITY (4.9.8) ISO GRADE **ISO VG 32 / 46**
 COMMON TO GAS GENERATOR/SINGLE SHAFT TURBINE
 FREE POWER TURBINE LOAD GEAR (IF APPLICABLE)
 DRIVEN EQUIPMENT AUXILIARIES
 (COMBINED) (SEPARATE) LUBE/SEAL SYSTEM (4.9.5)
 ● SYSTEM DESIGNED FOR SYNTHETIC LUBRICANT (4.9.2)
 LUBE SPECIFICATION **Rolls-Royce Approved Synthetic Oil**
 COMMON TO GAS GENERATOR POWER TURBINE
 LOAD GEAR DRIVEN EQUIPMENT
 AUXILIARIES

OIL REQUIREMENTS	FLOW m ³ /HR	PRESSURE kPag	HEAT LOAD MJ/HR
GG	_____	_____	_____
DRIVEN EQUIP.	_____	_____	_____
GEAR	_____	_____	_____
COUPLINGS	_____	_____	_____
POWER TURBINE	_____	_____	_____
TOTAL	_____	_____	_____

MOUNTING ARRANGEMENT

CONSOLE COLONY BASEPLATE

MATERIALS INSPECTION REQUIREMENTS (6.2.1.3)

- SPECIAL CHARPY TESTING (4.10.5.3)
- RADIOGRAPHY REQUIRED FOR _____
- MAGNETIC PARTICLE REQUIRED FOR _____
- LIQUID PENETRANT REQUIRED FOR _____
- ULTRASONIC REQUIRED FOR _____
- WELD INSPECTION (4.10.4.6.1) _____
- WELDING HARDNESS TESTING (6.2.3.4)

WEIGHTS

	DRY		
	INSTALLED WT. (kg)	SHIPPING WT. (kg)	DIMEN LxWxH (m)
GG OR SS TURBINE	_____	_____	_____
SS TURB. ROTOR	_____	_____	_____
POWER TURBINE	_____	_____	_____
P.T. ROTOR	_____	_____	_____
LUBE SYSTEM	_____	_____	_____
DRIVEN EQUIP.	_____	_____	_____
FILTER	_____	_____	_____
INLET SILENCER	_____	_____	_____
EXHAUST SILENCER	_____	_____	_____
DUCTING	_____	_____	_____
MAX ERECTION	_____	_____	_____
WEIGHT (kg)	_____	ITEM	_____
MAX MAINT.	_____	_____	_____
WEIGHT (kg)	_____	ITEM	_____

MISCELLANEOUS:

- VENDOR'S REVIEW & COMMENTS ON PURCHASER'S PIPING & FOUNDATION (4.1.18)
- FINAL ASSEMBLY CLEARANCES (6.2.1.1.e)
- COORDINATION MEETING SITE (7.1.3) Supplier's Facility
- SPEED-TORQUE CURVE (7.2.4-a)
- INCREASE POWER FOR STEAM/WATER (7.2.4-b)
- EFFECTS OF AMB. COND. ON EXHAUST FLOW (7.2.4-c)
- RUN DOWN CURVES (7.2.4 d)
- PURCHASER REVIEW OF CAMP./GOODMAN DIAG. (4.5.3.3)
- VENDOR WITNESS ALIGNMENT (4.1.18)
- TECHNICAL DATA MANUAL (7.3.6.4)
- NO OF PROPOSAL COPIES (7.2.1) _____

REMARKS:



eRB211 v6.1.4

31 March 2009

Customer: GAIL
Project: Pipeline Expansion Project
RB211-GT61
DLE Combustion

Site Conditions - Chainsa

Ambient Temp : 45degC
Altitude : 197.8m
Relative Humidity : 84%


Fuel

Fuel Type: Lean gas
Fuel LHV: 49602 kJ/kg

Installation Pressure Losses

Inlet: 100 mmH2O
Exhaust: 250 mmH2O

Expected Heat Rate kJ/kW.hr



COMPRESSOR STATION WORKS AT KAILARAS & CHAINSA -COMPRESSOR PACKAGE

OPERATING CASE: <u>CHAINSA (Lean Gas, MW=17.07)</u>			
1.	<u>Compressor</u>		
1.1	BKW required at compressor input shaft including all losses (with 0% positive tolerance)	kW	: 20680 (GUARANTEED)
2.	<u>Gas Turbine Site Rating</u> Ū		
2.1	GT Site Rating @ 45EC (at compressor operating point speed)	kW	: 23546 (GUARANTEED)
3.	<u>Heat Rate at Site Conditions</u> (while generating rated BKW as at 1 above)		
	GT Heat rate @ 45EC (at compressor operating point speed)	kJ/kWh kcal/kWh	: 10704 / 2557 (GUARANTEED)
3.1	Ū These figures correspond to the following site/operating conditions:		
	i) Expected TBO (Hot Section)	hrs	: 25000
	ii) Expected TBO (Power Turbine)	hrs	: 50000
	iii) GG Rated Speed	rpm	: 6395 / 9326
	iv) PT Rated Speed	rpm	: 4850
	v) Gas Turbine ISO Rating (with losses below)	kW	: 31213
	vi) Site Altitude	m	: 197.8
	vii) Max. Inlet Loss (At Site)	mm H ₂ O	: 100
	viii) Max. Exhaust Loss (At site) with Heat recovery in future	mm H ₂ O	: 250
	ix) Site Rated/Temperature	EC	: 45
	x) Relative Humidity	%	: 84
	xi) GGT Inlet Temperature (GG Exit Temp) [While generating site rated power]	EC	: 801.8
	Xii) NHV of fuel gas (LHV)	kcal/Sm ³	: 8565
4.	Overall compressor package noise level @ 1 meter from the equipment train (Including compressor, turbine and other aux. equipment & piping).	dBA	:

(NOTE: - This is a typical data sheet. Bidder shall furnish data sheets filled for each operating case of each compressor station with Proposal).

	ENGINEERS INDIA LIMITED NEW DELHI	COMBUSTION GAS TURBINE	DATA SHEET NO.	Rev.
			6988-000-KT-DS-0020	0

COMPRESSOR STATION WORKS AT KAILARAS & CHAINSA -COMPRESSOR PACKAGE

OPERATING CASE: <u>CHAINSA (Rich Gas, MW=17.4)</u>			
1.	<u>Compressor</u>		
1.1	BKW required at compressor input shaft including all losses (with 0% positive tolerance)	kW	: 20943
2.	<u>Gas Turbine Site Rating</u> Ū		
2.1	GT Site Rating @ 45EC (at compressor operating speed)	kW	: 23547
3.	<u>Heat Rate at Site Conditions</u> (while generating rated BKW as at 1 above)		
	GT Heat rate @ 45EC (at compressor operating point speed)	kJ/kWh kcal/kWh : 10176 / 2430	
3.1	Ū These figures correspond to the following site/operating conditions:		
	i) Expected TBO (Hot Section)	hrs	: 25000
	ii) Expected TBO (Power Turbine)	hrs	: 50000
	iii) GG Rated Speed	rpm	: 6396 / 9326
	iv) PT Rated Speed	rpm	: 4837
	v) Gas Turbine ISO Rating (with losses below)	kW	: 31199
	vi) Site Altitude	m	: 197.8
	vii) Max. Inlet Loss (At Site)	mm H ₂ O	: 100
	viii) Max. Exhaust Loss (At site) with Heat recovery in future	mm H ₂ O	: 250
	ix) Site Rated/Temperature	EC	: 45
	x) Relative Humidity	%	: 84
	xi) GGT Inlet Temperature (GG Exit Temp) [While generating site rated power]	EC	: 801.8
	Xii) NHV of fuel gas (LHV)	kcal/Sm ³	: 8716
4.	Overall compressor package noise level @ 1 meter from the equipment train (Including compressor, turbine and other aux. equipment & piping).	dBA	:

(NOTE: - This is a typical data sheet. Bidder shall furnish data sheets filled for each operating case of each compressor station with Proposal).

	ENGINEERS INDIA LIMITED NEW DELHI	COMBUSTION GAS TURBINE	DATA SHEET NO.	Rev.
			6988-000-KT-DS-0020	0

COMPRESSOR STATION WORKS AT KAILARAS & CHAINSA (GT –COMPRESSOR PACKAGE)

PERFORMANCE TABLE							
Sr No	DESCRIPTION	UNITS	OPERATING CASE : CHAINSA (Lean Gas, MW=17.07)				Remarks
			ISO	Rated	Max	Min	
			1	Ambient temperature	°C	15	
2	Relative humidity	%	60	84	84	37	
3	NHV of Fuel gas	kcal/kg	11847	11847	11847	11847	
4	Compressor Power at High speed Coupling (incl. Of mech. Seal losses)	kW	20680	20680	20680	20680	
5	Rated Speed of the Compressor	rpm	4850	4850	4850	4850	
6	Mech. Losses of Gas Turbine (Power to all auxiliaries)	kW	0	0	0	0	
7	Power Turbine Shaft speed	rpm	4850	4850	4850	4850	
8	Power required on Power Turbine Shaft [= (4) + (6)]	kW	20680	20680	20680	20680	
9	Site efficiency	%	35.31	33.63	33.63	35.75	
10	H _R : Heat Rate corresponding to (8)	kJ/kWh kcal/kWh	10195 2435	10704 2557	10704 2557	10069 2405	
11	W _{max} : Max. Power on PT Shaft at corresponding shaft speed Site Elevation = 197.8 m (As per site & Utility Data) Max. Inlet pressure Losses = 100 mm H ₂ O Max. Exhaust Pressure Losses = 250 mm H ₂ O & Including all other losses	kW	31213	23546	23546	34837	
12	η _S corresponding to W _{max} .	%	38.76	35.38	35.38	39.68	
13	H _R corresponding to W _{max} .	kJ/kWh kcal/kWh	9289 2219	10176 2430	10176 2430	9072 2167	
14	T _S : PT Exhaust Temperature	°C	451.9	520.0	520.0	416.9	
15	GG Exhaust Temp	°C	698.5	774.0	774.0	656.9	
16	Firing Temp	°C	Proprietary	Proprietary	Proprietary	Proprietary	
17	Exhaust Flow	kg/sec	78.1	71.5	71.5	81.3	
18	Actual Margin available with offered GT [= {(11) – (8)}/(8) * 100]	%	50.93	13.86	13.86	68.46	
(NOTE: - This is a typical data sheet. Bidder shall furnish data sheets filled for each operating case of each compressor station with Proposal).							


COMPRESSOR STATION WORKS AT KAILARAS & CHAINSA (GT –COMPRESSOR PACKAGE)


PERFORMANCE TABLE							
Sr No	DESCRIPTION	UNITS	OPERATING CASE : CHAINSA (Rich Gas, MW=17.4)				Remarks
			ISO	Rated	Max	Min	
			1	Ambient temperature	°C	15	
2	Relative humidity	%	60	84	84	37	
3	NHV of Fuel gas	kcal/kg	11824	11824	11824	11824	
4	Compressor Power at High speed Coupling (incl. Of mech. Seal losses)	kW	20943	20943	20943	20943	
5	Rated Speed of the Compressor	rpm	4837	4837	4837	4837	
6	Mech. Losses of Gas Turbine (Power to all auxiliaries)	kW	0	0	0	0	
7	Power Turbine Shaft speed	rpm	4837	4837	4837	4837	
8	Power required on Power Turbine Shaft [= (4) + (6)]	kW	20943	20943	20943	20943	
9	Site efficiency	%	35.45	34.26	34.26	35.90	
10	H _R : Heat Rate corresponding to (8)	kJ/kWh kcal/kWh	10155 2425	10507 2510	10507 2510	10028 2395	
11	W _{max} : Max. Power on PT Shaft at corresponding shaft speed Site Elevation = 197.8 m (As per site & Utility Data) Max. Inlet pressure Losses = 100 mm H ₂ O Max. Exhaust Pressure Losses = 250 mm H ₂ O & Including all other losses	kW	31199	23547	23547	34823	
12	η _S corresponding to W _{max} .	%	38.74	35.38	35.38	39.67	
13	H _R corresponding to W _{max} .	kJ/kWh kcal/kWh	9292 2219	10176 2430	10176 2430	9075 2168	
14	T _S : PT Exhaust Temperature	°C	452.6	520.9	520.9	417.5	
15	GG Exhaust Temp	°C	700.9	776.6	776.6	659.2	
16	Firing Temp	°C	Proprietary	Proprietary	Proprietary	Proprietary	
17	Exhaust Flow	kg/sec	78.5	71.9	71.9	81.7	
18	Actual Margin available with offered GT [= $\frac{(11) - (8)}{(8)} * 100$]	%	48.97	12.43	12.43	66.28	
(NOTE: - This is a typical data sheet. Bidder shall furnish data sheets filled for each operating case of each compressor station with Proposal).							


Tabulated below are the comparative capacity assessment figures (rounded-off figures) of CJHPL pipeline (at an interval of one year) carried out by entity & EIL:


Assessment years	Pipeline Capacity as determined by Entity (in MMSCMD)	Pipeline Capacity as assessed by EIL (in MMSCMD)	Remarks
	Entity	EIL	
	Software used - Pipeline Studio (TGNET)	Software used - Pipeline Studio (TGNET)	
2010-11	5.72	8.25	
2011-12	5.81	8.29	
2012-13	6.02	8.62	
2013-14	9.83	14.58	Addition of Chainsa Compressor at source & additional six consumers [Note-3]
2014-15	9.84	14.68	Change in network by addition of five consumers & two kms length
2015-16	9.71	14.7	Addition of two consumers in the network
2016-17	9.19	14.75	Addition of eleven consumers in the network
2017-18	9.19	14.75	
2018-19	9.93	14.78	
2019-20	10.22	12.63	Change in network by deletion of nine consumers & two kms length
2020-21	12.0	12.73	Sultanpur-Jhajjar-Hissar (135 km) was not considered as part of overall network [as not commissioned] [Note-4,5]
2021-22	12.0	12.73	
2022-23	9.87	13.2	23 no's of customers increased


** As the pipeline capacity was arrived as per PNGRB regulation [based on MAOP considerations], hence variation in determined capacity for various assessment years is due to change in sources and /or deliveries and / or network length and / or network configuration etc.




































Pipe Section	Flow	Length	Dia
	MSM3/D	km	in
82	10.17	8.5	34.48
77	9.17	31.4	16.99
81	9.17	9.4	34.48
79	8.89	4.1	16.99
76	5.16	7.3	16.99
83	11.35	30	34.48
78	3.68	19.4	16.99
80	1.41	23.08	16.99
84	11.07	23.1	34.48



GAIL's views/inputs/comments on Draft Report on Capacity Assessment of 05 Natural Gas Pipelines of GAIL shared by PNGRB

PNGRB, vide email dated 26.02.2024, has shared Draft Report for capacity assessment of following Natural Gas Pipelines of GAIL, soliciting GAIL's inputs on the same:

1. Narimanam-Kuthalam (NKM) sub-network of Cauvery Basin Natural Gas Pipeline Network
2. Chhainsa-Jhajjar-Hissar Natural Gas Pipeline (CJHPL)
3. Gujarat Natural Gas Pipeline Network
4. KG Basin Natural Gas Pipeline Network
5. GAIL Integrated Natural Gas Pipeline (GAIL INGPL)

In this regard, following are the comments / queries based on GAIL's understanding of the document:

A. Comments in general to all the networks assessments shared

- I. For the purpose of reviewing the aforesaid draft reports, the respective TNet files are required so that the multiple assumptions of source/delivery/pipelines etc. can be viewed for clarity on assessment methodology. The request for sharing the TNet files has been submitted to PNGRB vide email dated 07.03.2024.
- II. During the Capacity assessment exercise of 2011-12, the capacity determination was carried out by a Capacity Assessment Group (CAG) comprising of Prof. A Moharir of IIT Bombay, PNGRB representative and representatives of other entities owning and operating gas pipelines in the country (representatives of 02 transporters other than the entity of which the pipeline capacity is to be certified). The group ensured transparent approach to capacity assessment exercise through inclusion of practical and industrial aspects of determining capacity after discussion with the entities. It is understood that such constitution of Capacity Assessment Group, has not been done in the instant capacity assessment exercise.
- III. It is pertinent to note that the capacity assessment group consisting of representatives from IIT Bombay, GSPL, GAIL, RGTIL as well as PNGRB, laid down various parameters to be considered for capacity assessment for natural gas pipeline networks. During capacity assessment of natural gas pipelines under the provision of regulations the duly constituted committee deliberated on various practical limitations and suggested following aspects for determination/finalization of natural gas pipeline networks capacity:
 1. All deliveries within 50 km of any source shall be limited to contractual flow quantities.
 2. Pressure drop across the metering and regulating stations taken as 4 barg or higher on the basis of documentary evidence.
 3. Pressure drop across check meter / station will be 2 barg.
 4. Following source capacity limitations to be considered:
 - a. Depleting Source/Field: Source will be considered as a limiting source based on actual/current pressure and volume.

- b. LNG terminal capacity: Terminal will be considered as a limiting source based on regasification capacity.
 - c. Contractual off-take: All source and customer contractual pressure volume requirement are to be considered
 - d. Entry point pressure limitations of source: All contractual obligations of pressure and offtake to be considered.
5. It was also considered that the farthest / most critical customer shall be considered for free flow (volume maximization). It was agreed that such method would give true capacity of the pipeline and all other customers on the network in this case would also be fulfilled in terms of their contractual requirements.

The committee further deliberated that these aspects shall be uniformly applicable in all the future capacity assessment of natural gas pipelines.

The points at point nos. III (1-4) above are referenced from the PNGRB order of 2016 on capacity of EWPL of M/s RGTIL. The document titled Order pertaining to capacity of Natural Gas East West Pipeline (EWPL) of M/s Reliance Gas Transportation Infrastructure Limited (RGTIL) for the period between 1.4.2010 to 31.03.2011 and 01.04.2011 to 31.03.2012 has been referenced. It is not clear whether the aforementioned parameters have been included in the capacity determination of subject networks or not.

- IV. Further, CAG report of 2011 for RIL's EWPL, clause 1 (c)(b)(5) inter alia states that "At limiting condition of installed equipment (maximum available turbine power, compressor speed or maximum pressure, etc.) or delivery pressures, the maximum volumetric flow possible is considered as the capacity of the pipeline system that can be used for declaring system capacity. There was no data to suggest that other units such as filter, cooler, etc. were capacity limiting. In principle, any unit at such stations as represented in the station P&ID could be limiting and should be duly considered in capacity estimation". This implies that all limiting conditions of installed equipment viz. metering skids etc. must be considered in the capacity determination.

Since GAIL has not been provided the TNET files of the simulation, it is understood that the assessment of capacity of these networks has been carried out considering the equipment limitations at each of the tap-off locations as considered in previous assessments quoted herein. For instance, the installed pressure reduction skids at each of the branch lines along Sultanpur Neemrana section of CJHPL will pose limitations on account of their installed capacity.

- V. Additionally, the CAG report of 2011 for RIL's EWPL, clause 1 (c)(b)(3) points out that pipeline efficiency can deteriorate with time with increase in surface roughness and may also vary across different sections. GAIL's experience with pipeline operations indicate that pipeline efficiencies range mostly between 85%-90% and the same vary across sections based on different diameters, pipeline roughness, coating and age difference factors, gas type etc. It is understood that same has been considered for the instant cases as the report does not mention the efficiency considered against each of the networks in the assessment.

The aforementioned assumptions of the previous CAG have been evolved based on detailed deliberations carried out between stakeholders, PNGRB and

their appointed representative from IIT Bombay. These deliberations acknowledged the various practical aspects of determination of pipeline capacity. Therefore, it is GAIL's request that these deliberations and recommendations of the last CAG may please be considered in the instant case as well.

- VI. In the draft reports of capacity assessment clause 6.2 "Step wise methodology given for Capacity determination in Clause No. 5.(5) of PNGRB capacity regulation" at sub clause (ii) and (iii), it is mentioned that as per capacity regulation, at the originating point and at intermediate points in the direction of flow, the pressure should be set as a fixed parameter. It is requested to please provide the MAOP considered and the underlying philosophy in its selection thereof, in each of the cases and the individual sections. Further, it is understood that MAOP will be 4 kg/cm² below the design pressure or the de-rated value as the case may be.

B. Comments specific to the individual networks:

Chhainsa-Jhajjar-Hissar NGPL (CJHPL):

- VII. As per regulation 5 (5) (a) (iii) of the Capacity Determination Regulations, "*.... software will be run till any customer connected to the system reaches limiting condition of pressure required at the respective exit point or maximum flow capacity is reached at entry or intermediate compressor stations (if installed in the system) or the velocity of natural gas reaches limiting value....*". In this regard, GAIL would like to emphasize that Chhainsa Compressor station is the feed compressor for CJHPL as well as for Dadri-Bawana-Nangal NG Pipeline (DBNPL) and Dadri-Panipat NG Pipeline (DPPL). Hence, total capacity of these networks will not exceed the capacity of Chhainsa compressor station. It may be noted that the rated capacity of Chhainsa compressor station is 53.5 MMSCMD.
- VIII. It is requested to please provide the MAOP considered and the underlying philosophy in its selection thereof, in each of the cases and the individual sections. Further it is understood that MAOP will be 4 kg/cm² below the design pressure or the de-rated value as the case may be.

Gujarat Regional, Cauvery Basin (NKM) and KG Basin Networks:

- IX. Sub points (iii) and (iv) of clause 6.2 of the draft reports shared, may be read in conjunction with RIL order dated 30.12.2016 wherein it is emphasised that capacity assessment exercise for declared capacity goes by contractual obligations with regards to supply gas pressure. The networks of Gujarat, KG Basin and Cauvery Basin consist of depleting sources and there are contractual obligations on their offtake at pressures which are lower than the design pressure of the network they are connected to. It is requested to kindly confirm whether such contractual offtake requirements have been considered while assessment of capacity of these pipeline networks.

- X. The RIL order dated 30.12.2016, add emphasis on the above. The order cites a case wherein, to maximise capacity of GSPL network, CAG had taken higher pressure at Atakpardi source of 93 barg instead of 85 barg HLPL pressure. By running the simulation with other nearby sources at higher pressure, simulated node pressure at HLPL came out to be 86 barg which was higher as against the maximum contractual available pressure at HLPL, thus automatically forcing flow from HLPL source as zero. Such case would mean that the contractual offtake of gas from sources will not be honoured.
- XI. Further, the methodology adopted and elaborated at clause 6.2 of the draft reports mentions that gas at the entry point has been assumed as unlimited with MAOP conditions and then the selected software was run till any customer connected to the system reaches limiting condition as defined in regulation. In this regard, this, when read in conjunction with the aspects mentioned above at serial no. A(III), require that MAOP will be 4 kg/cm² below the design pressure or the de-rated value as the case may be. It is requested to kindly confirm the MAOP considered for each section.
- XII. In view of the above, it is requested to kindly confirm that the above-mentioned observations have been considered during the present capacity assessment. Further, it is again requested that TNet files may be provided for understanding the methodology of capacity assessment.

C. Comments related to data:

XIII. MAOP data:

- a) **NKM Subnetwork of Cauvery Basin Network:** As per the data shared, the MAOP considered by EIL in the capacity assessment of NKM subnetwork of Cauvery Basin Network is 49 kg/cm². In this regard, it is submitted that the NKM subnetwork is a closely interconnected network connected with multiple local gas fields. Though certain pipeline sections in this subnetwork have design pressure more than 19 kg/cm², the entire subnetwork has MAOP of 19 kg/cm².
- b) **Gujarat NGPL Subnetworks:** A table showing the MAOP considered by EIL in the draft reports and the inputs of GAIL is provided below for kind consideration:

SN	Subnetwork	In EIL Report – MAOP (kg/cm ²)	GAIL Inputs – MAOP (kg/cm ²)	Remarks
1	Motwan,	19	5.5	
2	Kadi Kalol	19	49	
3	Mehsana	19	5.5	MRTS pipeline is non-existing and Sabar Dairy connectivity is customer pipeline.
4	Paliyad	19	5.5	
5	Kalol Ramol	49	4.5	

- XIV. **Ex-Hazira Subnetwork data:** The requisite data in respect of determination of capacity of the Ex-Hazira subnetwork of Gujarat NGPL have been submitted to PNGRB vide email dated 05.03.2024.
- XV. **Pipeline section details:** The length of KG Basin has been given as 796.97 km and that for NKM subnetwork of Cauvery Basin has been given as 245.33 km in the draft report. It is requested to kindly provide the sections considered for capacity determination.
- XVI. **KG Basin pipeline replacement:** In the draft report it has been mentioned that Tatipaka -Oduru – KJ point section was changed in Assessment year 2017-18. Original & replacement sizes are both 18” respectively. Further, the length of replaced 24” pipeline section of Tatipaka – Chinchinad has been mentioned as 18.5 km. Both these data may please be reviewed in light of point no. 6.2.1.11 (d) (ii) under PNGRB’s Ruling on actual capex at page 18 of the KG Basin Tariff Order dated 28.06.2019, a snapshot of the relevant table is provided below:

						(Rs. Crore)
S. No.	Pipeline Sections	Original Size	Replaced size	Replaced Length (Km)	Capex Claimed	Capex considered
1	Tatipaka-Chinchinada	18”	24”	19.67	83.47	55.23
2	Tatipaka-Oduru-KJ Point	18”	24”	75.65	269.00	212.43
	Total			95.32	352.47	267.66

D. Other comments related to Tariff submissions:

XVII. GAIL Integrated NG Pipeline:

- i) As mentioned in the Draft Capacity Assessment Report, "Tie-In Connectivity" from Natural Gas source of Jaya Fields (Jambusar, Gujarat) of M/s Vedanta Ltd. to South Gujarat Main sub-network of Gujarat Natural Gas Pipeline Network (GNGPN) of GAIL was not a part of Integrated pipeline network and South Gujarat Main sub-network as provided by entity. However, it is informed that while submission of Integrated NGPL Tariff to PNGRB, the Jambusar Tie-in connectivity with South Gujarat Sub-network with its expected commissioning date has been conveyed as Sep-2023 and the same was also considered by PNGRB in their Tariff Order.
- ii) GAIL Integrated NGPL Capacity before and after commissioning of new source/Tie-in connectivities (additional capacity) may please be mentioned separately with respective dates in order to determine the Normative Volumes as per PNGRB Tariff Regulations.
- iii) As per Draft Capacity Assessment Report, Impact for Bokaro Tie-in connectivity and Jharia Tie-in connectivity has been considered in FY 2023-24. However, expected commissioning date of these Tie-in connectivity was August 2024 and same has been considered by PNGRB in the Tariff Order. Accordingly, the same may please be reviewed.

- iv) At page no. 13 of the draft report, it is mentioned that Baroda, Kadi-Kalol, Kalol-Ramol, Mehsana, Motwan, Paliyad and Ex-Hazira sub-network are part of South Gujarat low pressure network and are shown as part of the sources of GAIL Integrated NGPL. The same may please be reviewed since the Baroda sub-network alone is part of the GAIL Integrated NGPL and other sub-networks are not a part of the same.

XVIII. NKM Subnetwork of Cauvery Basin:

The capacity of Cauvery Basin-NKM subnetwork before and after commissioning of the Madanam Tie-in connectivity may please be mentioned separately in the report for the purpose of calculation of Normative Volume as on respective commissioning dates as per PNGRB Tariff Regulations.

XIX. CJHPL:

Capacity of CJHPL before and after commissioning of the following may please be mentioned separately with respective dates in the report for the purpose of calculation of Normative Volume as per PNGRB Tariff Regulations:

- i) Chhainsa Compressor Station
- ii) Sultanpur-Jhajjar-Hissar section

XX. Gujarat NGPL:

- i) Capex and Opex of certain customers (i.e. Schott Glass, HSG, Haldyn Glass and Punjab Steel) of South Gujarat-Main were not considered by PNGRB while tariff processing of GAIL Integrated NGPL. Accordingly, the same needs to be specified separately in Capacity Assessment Report so that necessary treatment of Capex and Opex may be done in next tariff review by PNGRB.
- ii) Capex and Opex of one another customer (i.e. Shyam Industries) under Kalol-Ramol sub-network also was not allowed in last tariff order. Accordingly, this section also needs to be specified separately in Capacity determination report for necessary treatment.

XXI. KG Basin Network:

- i) Odalarevu Bodasakuru pipeline Tie-in connectivity was completed in Nov 2018, whereas, it has been mentioned in the draft Capacity Assessment Report that the Odalarevu source has been added in the year 2016-17.
- ii) Bantumili Tie-in connectivity was completed in March-2023, and hence the impact of the same on the capacity of KG Basin Network may have to be determined.

Email**ANSHU KUMAR**

Re: Capacity Assessment of the GAIL's CJHPL, KG BASIN & INTEGRATED NGPL networks

From : MRAGANG SHEAKHAR <m.sheakhar@eil.co.in>

Thu, Mar 21, 2024 07:11 PM

Subject : Re: Capacity Assessment of the GAIL's CJHPL, KG BASIN & INTEGRATED NGPL networks 3 attachments**To :** Technical Division PNGRB <e-technical.pngrb@nic.in>**Cc :** JAYATI GHOSH <jayati.ghosh@eil.co.in>, HASMUKH K PARMAR <hk.parmar@eil.co.in>, ANSHU KUMAR <anshu.kumar@eil.co.in>, Anil Garg <garg.anil@pngrb.gov.in>, Muktikam Phukan <muktikamphukan@pngrb.gov.in>, Gagan Aggarwal <gaggarwal@pngrb.gov.in>, Yuvraj Singh Rathore <yuvraj.rathore@pngrb.gov.in>, Voona Venkata Narendra <narendra.vv@pngrb.gov.in>, VAIBHAV VAIBHAV <vaibhav.srivastava@eil.co.in>

Dear Sir,

With regard to Entity observations received vide trailing mail, no change is envisaged for capacity of subject networks and hence final study reports are attached for following :

- CHHAINSA-JHAJJAR-HISSAR NATURAL GAS PIPELINE (CJHPL)
- INTEGRATED/INTERCONNECTED PIPELINE NETWORK
- KG BASIN NGPL NETWORK

Annexures : <https://email.gov.in/home...riefcase/PNGRB%2001032024>

Regards,

Mragang Sheakhar | Process-1 | Engineers India Limited, P&I Building, Gurgaon
Ground Floor, Icom 3025, Mobile 9555438664



From: "Technical Division PNGRB" <e-technical@pngrb.gov.in>**To:** "JAYATI GHOSH" <jayati.ghosh@eil.co.in>**Cc:** "HASMUKH K PARMAR" <hk.parmar@eil.co.in>, "MRAGANG SHEAKHAR" <m.sheakhar@eil.co.in>, "ANSHU KUMAR" <anshu.kumar@eil.co.in>, "Anil Garg" <garg.anil@pngrb.gov.in>, "Muktikam Phukan" <muktikamphukan@pngrb.gov.in>, "Gagan Aggarwal" <gaggarwal@pngrb.gov.in>, "Yuvraj Singh Rathore" <yuvraj.rathore@pngrb.gov.in>, "Voona Venkata

Narendra" <narendra.vv@pngrb.gov.in>

Sent: Tuesday, March 19, 2024 2:29:26 PM

Subject: Capacity Assessment of the GAIL's five NGPL networks

Dear Madam,

This has reference to updated reports on capacity assessment of the subject pipeline network and the meeting held on 26.02.2024 w.r.t review of the Capacity Assessment of the 06 Natural Gas Pipeline Networks.

As decided in the meeting the updated reports were shared with GAIL along with input/output files provided by EIL and GAIL was advised to submit its inputs on the updated report of the Capacity Assessment latest by 07.03.2024. Accordingly, GAIL has provided its inputs vide emails dated 07.03.2024, 18.03.2024 & 19.03.2024 which are enclosed as trailing mail(s).

In view of the above, EIL is hereby advised to review the inputs provided by GAIL and submit its reply to inputs of GAIL. Also, same may be annexed in the final report.

The Final report of the capacity assessment of five GAIL NGPL networks along with all Annexures shall be submitted to PNGRB by **22.03.2024** positively.

धन्यवाद और सादर | Thanks and Regards,

तकनीकी विभाग | Technical Division

पेट्रोलियम एवं प्राकृतिक गैस विनियामक बोर्ड

Petroleum and Natural Gas Regulatory Board

प्रथम-तल, वर्ल्ड ट्रेड सेंटर, बाबर रोड, नई दिल्ली - ११० ००१


1st Floor, World Trade Center, Babar Road, New Delhi - 110 001

W: www.pngrb.gov.in

E: e-Technical@pngrb.gov.in

D: 011-23457741

"Please consider the environment and do not print this email unless absolutely necessary"
"कृपया पर्यावरण की रक्षा करें और इस ई-संदेश को केवल नितांत आवश्यक होने पर ही मुद्रित करें"



From: "Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप)" <cragroup@gail.co.in>
To: "Technical Division PNGRB" <e-technical.pngrb@nic.in>
Cc: "Secretary" <secretary@pngrb.gov.in>, "Anil Garg" <garg.anil@pngrb.gov.in>, "Gagan Aggarwal" <gagarwal@pngrb.gov.in>, "Yuvraj Singh Rathore" <yuvraj.rathore@pngrb.gov.in>, "Voona Venkata Narendra" <narendra.vv@pngrb.gov.in>, skishore@gail.co.in, jpathak@gail.co.in, "r kannan" <r_kannan@gail.co.in>
Sent: Tuesday, March 19, 2024 10:30:58 AM
Subject: RE: Capacity Assessment of the GAIL's five NGPL networks

Dear Sir,

In continuation to the inputs/comments of GAIL as provided vide the trailing email, it is requested to kindly consider the following input also:

“In previous capacity assessment exercises by Capacity Assessment Group, an allowance of 5% was also considered for declared capacity as theoretical capacity are determined considering extreme conditions. Same may also be included in the present capacity assessment to maintain uniformity.”

Regards,

R Kannan,
DGM (Mktg-RA),
Regulatory Affairs Group,
GAIL (India) Limited, New Delhi

From: Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप)

Sent: 18 March 2024 17:47

To: 'Technical Division PNGRB' <e-technical.pngrb@nic.in>

Cc: R Kannan (आर. कन्नन) <r_kannan@gail.co.in>; Secretary <secretary@pngrb.gov.in>; Anil Garg <garg.anil@pngrb.gov.in>; Gagan Aggarwal <gagarwal@pngrb.gov.in>; Yuvraj Singh Rathore <yuvraj.rathore@pngrb.gov.in>; Voona Venkata Narendra <narendra.vv@pngrb.gov.in>; Sumit Kishore (सुमित किशोर) <skishore@gail.co.in>; Jitendra Pathak (जितेन्द्र पाठक) <jpathak@gail.co.in>; R Kannan (आर. कन्नन) <r_kannan@gail.co.in>

Subject: RE: Capacity Assessment of the GAIL's five NGPL networks

Dear Sir,

With reference to the trailing email communications, and the meeting held at PNGRB on 14.03.2024, please find enclosed GAIL inputs/comments on the Draft Capacity Assessment Reports prepared by EIL for the following NG Pipelines of GAIL:

1. GAIL Integrated NGPL
2. Cauvery Basin Network – NKM subnetwork
3. Chhainsa Jhajjar Hissar NGPL
4. KG Basin Network
5. Gujarat NGPL subnetworks

Regards,

R Kannan,
DGM (Mktg-RA),
Regulatory Affairs Group,
GAIL (India) Limited, New Delhi

From: Technical Division PNGRB <e-technical@pngrb.gov.in>

Sent: 11 March 2024 14:34

To: Jitendra Pathak (जितेन्द्र पाठक) <jpathak@gail.co.in>; Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप) <cragroup@gail.co.in>

Cc: R Kannan (आर. कन्नन) <r_kannan@gail.co.in>; Secretary <secretary@pngrb.gov.in>; Anil Garg <garg.anil@pngrb.gov.in>; Gagan Aggarwal <gaggarwal@pngrb.gov.in>; Yuvraj Singh Rathore <yuvraj.rathore@pngrb.gov.in>; Voona Venkata Narendra <narendra.vv@pngrb.gov.in>

Subject: Re: Capacity Assessment of the GAIL's five NGPL networks

CAUTION: External Email. Do not click links or open attachment unless you trust the Sender and know the Content is safe. Report suspicious mails to "cybersec@gail.co.in".

This has reference to trailing mails(s).

We acknowledge the comments provided by GAIL.

As GAIL has not submitted any specific inputs to the EIL's Capacity Assessment draft reports for the five NGPL networks, we are going ahead with the reports for their finalization.

धन्यवाद और सादर | Thanks and Regards,

तकनीकी विभाग | Technical Division

पेट्रोलियम एवं प्राकृतिक गैस विनियामक बोर्ड

Petroleum and Natural Gas Regulatory Board

प्रथम-तल, वर्ल्ड ट्रेड सेंटर, बाबर रोड, नई दिल्ली -११० ००१

1st Floor, World Trade Center, Babar Road, New Delhi - 110 001

W: www.pngrb.gov.in

E: e-Technical@pngrb.gov.in

D: 011-23457741

From: "Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप)" <cragroup@gail.co.in>
To: "Technical Division PNGRB" <e-technical.pngrb@nic.in>
Cc: "Secretary" <secretary@pngrb.gov.in>, "Anil Garg" <garg.anil@pngrb.gov.in>, "Gagan Aggarwal" <gaggarwal@pngrb.gov.in>, "Yuvraj Singh Rathore" <yuvraj.rathore@pngrb.gov.in>, "Voona Venkata Narendra" <narendra.vv@pngrb.gov.in>, jpathak@gail.co.in, "r kannan" <r_kannan@gail.co.in>
Sent: Thursday, March 7, 2024 6:45:49 PM
Subject: RE: Capacity Assessment of the GAIL's five NGPL networks

Dear Sir,

With reference to the trailing emails on the subject, it is submitted that the draft Reports are being studied by concerned Departments in GAIL for providing inputs. Collating the inputs and subsequent approval needs sufficient time.

Further, it is observed that respective TNet files, based on which the draft reports have been prepared by EIL, are not available in the data folders shared by PNGRB. The TNet files are required to understand multiple assumptions of source/delivery/pipelines etc. to have better clarity on assessment methodology.

Hence, it is requested to kindly share the TNet files and allow us 2 more weeks for submitting the comments of GAIL on these draft reports.

Regards,

R Kannan,
DGM (Mktg-RA),
Regulatory Affairs Group,
GAIL (India) Limited, New Delhi

From: Technical Division PNGRB <e-technical@pngrb.gov.in>

Sent: 04 March 2024 15:20

To: Jitendra Pathak (जितेन्द्र पाठक) <jpathak@gail.co.in>; Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप) <cragroup@gail.co.in>

Cc: R Kannan (आर. कन्नन) <r_kannan@gail.co.in>; Secretary <secretary@pngrb.gov.in>; Anil Garg <garg.anil@pngrb.gov.in>; Gagan Aggarwal <gagarwal@pngrb.gov.in>; Yuvraj Singh Rathore <yuvraj.rathore@pngrb.gov.in>; Voona Venkata Narendra <narendra.vv@pngrb.gov.in>

Subject: Re: Capacity Assessment of the GAIL's five NGPL networks

CAUTION: External Email. Do not click links or open attachment unless you trust the Sender and know the Content is safe. Report suspicious mails to "cybersec@gail.co.in".

Sir,

This is in furtherance to trailing mail(s). The input/output datasheet for capacity assessed for GAIL Gujarat Sub-Network by EIL is being forwarded for your perusal.

In line with the previous mail, you are advised to provide your inputs (as per Email dated 26.02.2024) latest by 07.03.2024 *for all the five NGPL networks*. In absence of any inputs by 07.03.2024, it will be presumed that you have no inputs w.r.t Capacity Assessment Report(s) of EIL and same may be considered as final report(s) towards capacity assessment.

धन्यवाद और सादर | Thanks and Regards,

तकनीकी विभाग | Technical Division

From: "Technical Division PNGRB" <e-technical@pngrb.gov.in>
To: "Jitendra Pathak (जितेन्द्र पाठक)" <jpathak@gail.co.in>, "Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप)" <cragroup@gail.co.in>
Cc: "R Kannan (आर. कन्नन)" <r_kannan@gail.co.in>, "Secretary" <secretary@pngrb.gov.in>, "Anil Garg" <garg.anil@pngrb.gov.in>, "Gagan Aggarwal" <gaggarwal@pngrb.gov.in>, "Yuvraj Singh Rathore" <yuvraj.rathore@pngrb.gov.in>, "Voona Venkata Narendra" <narendra.vv@pngrb.gov.in>
Sent: Saturday, March 2, 2024 3:46:20 PM
Subject: Re: Capacity Assessment of the GAIL's five NGPL networks

Sir,

This is in furtherance to trailing mail(s). The input/output datasheet for capacity assessed of EIL is being forwarded for your perusal.

You are advised to provide your inputs (as per Email dated 26.02.2024) latest by 07.03.2024 for following NGPL networks. In absence of any inputs by 07.03.2024, it will be presumed that you have no inputs w.r.t Capacity Assessment Report(s) of EIL and same may be considered as final report(s) towards capacity assessment. Please find enclosed datasheet for:

1. GAIL Integrated NGPL
2. Cauvery Basin Network
3. Chhainsa Jhajjar Hisar NGPL
4. KG Basin Network
5. Gujarat Sub-Network NGPL(will be share by Monday)

धन्यवाद और सादर | Thanks and Regards,

तकनीकी विभाग | Technical Division**पेट्रोलियम एवं प्राकृतिक गैस विनियामक बोर्ड****Petroleum and Natural Gas Regulatory Board****प्रथम-तल, वर्ल्ड ट्रेड सेंटर, बाबर रोड, नई दिल्ली -११० ००१**

1st Floor, World Trade Center, Babar Road, New Delhi - 110 001

From: "Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप)" <cragroup@gail.co.in>
To: "Technical Division PNGRB" <e-technical.pngrb@nic.in>
Cc: "Secretary" <secretary@pngrb.gov.in>, "Anil Garg" <garg.anil@pngrb.gov.in>, "Gagan Aggarwal" <gaggarwal@pngrb.gov.in>, "Yuvraj Singh Rathore" <yuvraj.rathore@pngrb.gov.in>, "Voona Venkata Narendra" <narendra.vv@pngrb.gov.in>, jpathak@gail.co.in, "r kannan" <r_kannan@gail.co.in>
Sent: Thursday, February 29, 2024 4:07:43 PM
Subject: RE: Capacity Assessment of the GAIL's five NGPL networks

Dear Sir,

Vide the trailing email and through One Drive, PNGRB has shared the DRAFT REPORTS of Capacity Assessment of the following five Natural Gas Pipeline networks of GAIL:

1. GAIL Integrated NGPL
2. Cauvery Basin Network
3. Chainsa – Jhajjar – Hissar NGPL
4. Gujarat NGPL sub networks
5. KG Basin Network

Studying these Draft Reports and the documents needs sufficient time. Hence, it is requested to kindly allow us one month time for providing the comments of GAIL on these draft reports.

Further, it is requested to kindly share the assumptions, if any, which might have been considered by EIL in the capacity determination in place of any unavailable data.

Regards,

R Kannan,
DGM (Mktg-RA),
Regulatory Affairs Group,
GAIL (India) Limited, New Delhi

From: Technical Division PNGRB <e-technical@pngrb.gov.in>

Sent: 26 February 2024 17:42

To: Jitendra Pathak (जितेन्द्र पाठक) <jpathak@gail.co.in>; Corporate Regulatory Affairs group (निगमित विनियामक मामला ग्रुप) <cragroup@gail.co.in>

Cc: R Kannan (आर. कन्नन) <r_kannan@gail.co.in>; Secretary <secretary@pngrb.gov.in>; Anil Garg <garg.anil@pngrb.gov.in>; Gagan Aggarwal <gaggarwal@pngrb.gov.in>; Yuvraj Singh Rathore <yuvraj.rathore@pngrb.gov.in>; Voona Venkata Narendra <narendra.vv@pngrb.gov.in>

Subject: Fwd: Capacity Assessment of the GAIL's five NGPL networks

Importance: High

CAUTION: External Email. Do not click links or open attachment unless you trust the Sender and know the Content is safe. Report suspicious mails to "cybersec@gail.co.in".

Sir,

Based on inputs from GAIL, EIL has submitted the reports of Capacity Assessment of five Natural Gas Pipeline networks (Copies enclosed and annexures of the reports have been shared through One Drive link).

You may like to see the same and offer your inputs on the following:

1. Verification of data/details considered by EIL in its assessments.
2. Difference between methodology adopted by EIL and GAIL, in line with the existing provisions of PNGRB (Determining Capacity of Petroleum, Petroleum Products and Natural Gas Pipeline) Regulations, 2010 for assessment of the capacity of

the respective NGPL networks.
You are advised to submit the same by 29.02.2024 positively.

धन्यवाद और सादर | Thanks and Regards,

तकनीकी विभाग | Technical Division

पेट्रोलियम एवं प्राकृतिक गैस विनियामक बोर्ड

Petroleum and Natural Gas Regulatory Board

प्रथम-तल, वर्ल्ड ट्रेड सेंटर, बाबर रोड, नई दिल्ली -११० ००१

1st Floor, World Trade Center, Babar Road, New Delhi - 110 001


W: www.pngrb.gov.in

E: e-Technical@pngrb.gov.in

D: 011-23457741

"Please consider the environment and do not print this email unless absolutely necessary"

“कृपया पर्यावरण की रक्षा करें और इस ई-संदेश को केवल नितांत आवश्यक होने पर ही मुद्रित करें”





Har Ek Kaam Desh Ke Naam

Disclaimer: This communication is confidential and privileged and is directed to and for the use of the addressee only. The recipient, if not the addressee, should not use this message if erroneously received as access and use of this e-mail in any manner by anyone other than the addressee is unauthorized. The recipient acknowledges that GAIL (India) Limited may be unable to exercise control or ensure or guarantee the integrity of the text of this email message and the text is not warranted as to completeness and accuracy. Though GAIL (India) Limited has taken reasonable precautions to ensure no viruses are present in this e-mail, however, it cannot accept responsibility for any loss or damage arising from the use of this email or attachments.

Har Ek Kaam Desh Ke Naam


Disclaimer: This communication is confidential and privileged and is directed to and for the use of the addressee only. The recipient, if not the addressee, should not use this message if erroneously received as access and use of this e-mail in any manner by anyone other than the addressee is unauthorized. The recipient acknowledges that GAIL (India) Limited may be unable to exercise control or ensure or guarantee the integrity of the text of this email message and the text is not warranted as to completeness and accuracy. Though GAIL (India) Limited has taken reasonable precautions to ensure no viruses are present in this e-mail, however, it cannot accept responsibility for any loss or damage arising from the use of this email or attachments.


Har Ek Kaam Desh Ke Naam

Disclaimer: This communication is confidential and privileged and is directed to and for the use of the addressee only. The recipient, if not the addressee, should not use this message if erroneously received as access and use of this e-mail in any manner by anyone other than the addressee is unauthorized. The recipient acknowledges that GAIL (India) Limited may be unable to exercise control or ensure or guarantee the integrity of the text of this email message and the text is not warranted as to completeness and accuracy. Though GAIL (India) Limited has taken reasonable precautions to ensure no viruses are

present in this e-mail, however, it cannot accept responsibility for any loss or damage arising from the use of this email or attachments.

 **Report _GKGBNGL.pdf**
643 KB

 **Report _GIIPN.pdf**
485 KB

 **Report _CJHPL.pdf**
646 KB
