

Comments on Proposed Amendment in PNGRB (Technical Standards and Specifications including Safety Standards for Retail Outlets dispensing petroleum, Auto LPG and CNG) Regulations, 2018

Public Notice dated 17th Feb' 2020

S.No.	Proposed amendment	GAIL Gas Comments
1	Annexure-A: 7 (2) Compliance to these regulations:	GAIL Gas is a wholly owned subsidiary of GAIL (India) Ltd. and all directors on its Board are part time Directors. Therefore, appointment of one of the Directors of GAIL Gas for ensuring compliance to these regulations shall not be possible.
2	Annexure-I: Sub-regulation 12 (8) of Schedule-4	Detailed requirements for fire-fighting facilities to be elaborated in the regulation itself.
3	Annexure-I: Sub-regulation 12 (8) of Schedule-4,	Requirement of Fire Water storage tanks and pumps may be reviewed/ re visited
4	Annexure-I: Sub-regulation 3 of Schedule-4	Inter distance between the adjoining properties and compound wall of LCNG/ LNG stations needs to be provided.